

Room Name	Consult Room	Room Number CONS
Revision	5	
Issue Date	20.03.17	
BRIEFING		
Briefed Area	12.00 m ²	
Hours of Operation	24 Hours	
Occupancy	1 patient: 1-2 staff, 1-2 visitors	
Acoustics	Sound attenuation level high, Acoustic privacy is essential.	
Remarks	For bariatric consult requirements refer to Treatment Room options	
Description / Special Requirements	The Consult Room will provide for private consultation and physical examination of patients with or without support persons present. A second egress door may be required for staff safety and security and/or staff access. A hoist, fixed or ceiling mounted (depending on local arrangements) may be required for selected clinical situations.	
SERVICES		
General Requirements	BODY PROTECTED = Yes	CARDIAC PROTECTED = No
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No
Lighting	LIGHTING: colour corrected = Yes LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = No	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No
Nurse Call	NURSE CALL SYSTEM = Yes	

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLGE-001	CEILING: plasterboard, bulkhead, paint	Between above bench joinery and ceiling
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-033	DOOR: 1400mm c/o, 1 1/2 leaf, observation panel, solid core/glass, paint	Min. 1350mm clear opening with 910 large leaf, or a 1200mm clear opening single door. Bariatric provision to be decided at project level
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	Optional, to be decided at project level
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	Carpet also acceptable
FLVY-009	FLOOR FINISH: vinyl, seamless, coved, wet area, non-slip	Under basin, significant colour change to be avoided
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	Feather edge vinyl skirting if carpeted
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-007	WALL FINISH: splashback	Selection of material to comply with Part D Infection Prevention and Control AusHFG

Room Name | Consult Room
Room Number CONS
Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	1	optional
HYBA-010	BASIN: handwash, Type B	1	1	elbow action levers
FQCW-016	BIN: waste, general, 20L	3	1	to basin
FQCW-016	BIN: waste, general, 20L	3	1	
FQCW-044	BIN: waste, sharps, wall mounted	3	1	Wall mounted
FIHR-016	BRACKET: for sharps bin	2	1	
FIHR-019	BRACKET: for suction bottle	2	1	optional
FQBS-018	CHAIR: office, ergonomic	3	1	
FQBS-028	CHAIR: visitor, clinical areas	3	3	Consider weight capacity of chair
ITNE-007	COMPUTER: desktop, with display screen	3	1	High resolution monitor for PACS viewing
MMBE-023	COUCH: examination, electric, mobile	3	1	Hi / low operation
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	1	over desk, optional, number to suit layout refer to RLS or project specific requirements.
FQGE-009	CURTAIN: bed screen	3	1	
FQDW-001	DESK: adj height, 1100W x 600D x 750H nom.	3	1	
MMGE-031	DIAGNOSTIC SET: wall mounted	3	1	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-003	DISPENSER: bedroll	2	1	Or provided as an attachment to exam couch
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-022	DISPENSER: moisturiser	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to hand basin
FIDI-030	DISPENSER: soap	2	1	to hand basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to hand basin
MGFP-002	FLOWMETER: medical air	3	1	optional
MGFP-004	FLOWMETER: oxygen	3	1	optional
FIHR-026	HOOK: coat	1	2	
LIFX-026	LIGHT: examination, wall mounted	1	1	Default= wall mounted: or ceiling mounted
FIBM-006	MIRROR: fixed, glass	1	1	for patient changing
FIBM-013	NOTICEBOARD: fixed, fabric covered	1	1	over desk, optional
ITNE-023	PRINTER: networked	3	0	EMR/E-med compatible, printing strategy (centralised vs decentral) to be decided at project level
MMGE-091	SPHYGMOMANOMETER: portable	3	0	1 per 6 Consult Rooms. Ratio to be determined at project level.
MMGE-100	SUCTION BOTTLE	3	1	optional

Room Name | Consult Room
Room Number CONS

AusHFG code	Description	Group	Qty	Comment
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
ITNE-050	TELEPHONE: handset, desktop, handsfree	3	1	
FIRT-023	TRACK: curtain, bedscreen, L shaped	1	1	to exam couch
MMGE-153	VIEWER: X-ray, 2 screen, mobile	3	0	1 per department, number and location to be decided at project level

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITSE-006	BUTTON: duress, fixed	1	1	in discreet location easily accessible by staff
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	+ indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	+ indicator button & light
ELGP-205	GPO: double, on services panel	1	1	patient examination area
ELGP-208	GPO: double, wall mounted	1	2	workstation / desk area
ELGP-222	GPO: emergency power, double, on services panel	1	1	patient examination area
ELGP-105	GPO: single, on services panel	1	1	diagnostic set
ELGP-109	GPO: single, wall mounted	1	1	for exam light
ELGP-109	GPO: single, wall mounted	1	1	low level for electric couch
ELGP-109	GPO: single, wall mounted	1	1	Above bench for BYO device
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	
ITIN-025	OUTLET: data, double RJ45, on services panel	1	1	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	1 outlet for telephone
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	optional
MGAS-042	OUTLET: oxygen (O2), on services panel	1	1	optional
MGAS-062	OUTLET: suction, on services panel	1	1	optional
MMSP-026	SERVICES PANEL: wall mounted	2	1	
ELBO-015	SWITCH: light, single	1	1	