

| Room Name | Dental Workroom | | Room Number DENW |
|-------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------|------------------|
| Revision | 3 | | |
| Issue Date | 20.03.17 | | |
| BRIEFING | | | |
| Briefed Area | 12.00 m ² | | |
| Hours of Operation | 8am to 6 pm daily | | |
| Occupancy | 1 - 2 | | |
| Acoustics | Sound attenuation high: Acoustic privacy required | | |
| Remarks | | | |
| Description / Special Requirements | The Dental Workroom provides facilities and equipment for dental technicians to make adjustments to dentures or other dental prosthetics, and to store prosthetic supplies. | | |
| SERVICES | | | |
| General Requirements | BODY PROTECTED = No | CARDIAC PROTECTED = No | |
| Air | AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No | AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No | |
| Lighting | LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes | LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No | |
| Nurse Call | NURSE CALL SYSTEM = No | | |

Room Fabrics

| AusHFG code | Description | Comment |
|-------------|--------------------------------------------------------------------------|-----------------------|
| CLFS-006 | CEILING: plasterboard, flush set, suspended, paint, washable | |
| CLCN-002 | CORNICE: aluminium, 24mm shadow angle, powdercoat | |
| DWGL-005 | DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint | |
| DWPR-006 | DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished | |
| DWPR-010 | DOOR PROTECTION: to door frame, PVC, prefinished | |
| FLVY-007 | FLOOR FINISH: vinyl, seamless, coved, standard slip resistant | |
| FLSK-010 | SKIRTING: vinyl, floor vinyl coved, 150H, prefinished | |
| WLWA-004 | WALL FINISH: paint, acrylic, washable | |
| WLWA-010 | WALL FINISH: splashback, vinyl | tiles also acceptable |

Fittings, Furniture and Equipment (FF&E) Items

| AusHFG code | Description | Group | Qty | Comment |
|-------------|-------------------------------------------------|-------|-----|----------------------------------------------|
| HYBA-010 | BASIN: handwash, Type B | 1 | 1 | refer to BHWS-B (similar) |
| FIJO-021 | BENCH: 600D, open under, stainless steel lipped | 1 | 2 | with wet edge, open under part, one leg 650D |
| FQCW-016 | BIN: waste, general, 20L | 3 | 1 | |
| MMLA-016 | BURNER: bunsen | 3 | 1 | |

Room Name | Dental Workroom
Room Number DENW

| AusHFG code | Description | Group | Qty | Comment |
|-------------|-----------------------------------------------|-------|-----|-------------|
| FIJO-152 | CUPBOARD: wall mount, shelf unit, adj shelves | 1 | 4 | over bench |
| FIDI-014 | DISPENSER: disposable glove | 2 | 1 | |
| FIDI-021 | DISPENSER: mask | 3 | 1 | |
| FIDI-025 | DISPENSER: paper/hand towel | 2 | 1 | to basin |
| FIDI-030 | DISPENSER: soap | 2 | 1 | to basin |
| FIDI-031 | DISPENSER: soap antiseptic | 2 | 1 | to basin |
| MMDN-008 | GRINDER: dental, workshop | 3 | 1 | |
| MMDN-009 | LATHE: dental, polishing | 3 | 1 | |
| FIJO-197 | SHELF: stainless steel, underbench | 1 | 4 | under bench |
| HYBA-069 | SINK: single, with drainer, 930mmL | 1 | 1 | |
| HYTP-037 | TAPWARE: mixer, elbow levers | 1 | 1 | to basin |
| HYTP-037 | TAPWARE: mixer, elbow levers | 1 | 1 | to sink |
| HYDR-008 | TRAP: plaster | 1 | 1 | under sink |
| MMDN-017 | UNIT: processing, denture | 3 | 1 | |

Engineering Services

| AusHFG code | Description | Group | Qty | Comment |
|-------------|-----------------------------------------|-------|-----|----------------------------------|
| HYDR-004 | DRAIN: floor waste | 1 | 1 | |
| MEEEX-007 | EXHAUST: hood | 1 | 1 | over dental processing equipment |
| ELGP-208 | GPO: double, wall mounted | 1 | 4 | |
| ITSE-029 | INTERCOM: audio, wall mount | 1 | 1 | optional |
| LIFX-008 | LIGHT: task light, built in | 1 | 4 | |
| HYTP-008 | OUTLET: cold water | 1 | 1 | additional outlet for equipment |
| MGAS-008 | OUTLET: compressed air, wall mounted | 1 | 1 | |
| ITIN-026 | OUTLET: data, double RJ45, wall mounted | 1 | 1 | |
| HYTP-014 | OUTLET: natural gas | 1 | 1 | for bunsen burner |
| ELBO-015 | SWITCH: light, single | 1 | 2 | |