

Room Name | Disposal Room, 10m2

Room Number DISP-10

Revision 5
Issue Date 20.03.17

BRIEFING
Briefed Area 10.00 m²
Hours of Operation 24 Hours
Occupancy
Acoustics
Remarks
Description / Special Requirements

The Disposal Room provides for the temporary holding of clinical waste, general waste, sharps, soiled linen and recyclables prior to removal. The Disposal Room should be located in close proximity to a handwashing basin or be provided within the room (optional) if waste will be handled in this area. The room should be lockable.

SERVICES
General Requirements

BODY PROTECTED = No

CARDIAC PROTECTED = No

Air

AIRCONDITIONING = No

AIRCONDITIONING: hepa filtered = No

AIRCONDITIONING: positive pressure = No

AIRCONDITIONING: negative pressure = No

EXHAUST: room exhaust = Yes

VENTILATION = Yes

Lighting

LIGHTING: colour corrected = No

LIGHTING: dimmable = No

LIGHTING: downlights = No

LIGHTING: downlights, dimmable = No

LIGHTING: fluorescent, downlights = No

LIGHTING: fluorescent, flush with ceiling, tamper proof = No

LIGHTING: fluorescent, general = Yes

LIGHTING: indirect = No

Nurse Call

NURSE CALL SYSTEM = No

Room Fabrics

AusHFG code	Description	Comment
CLGE-001	CEILING: plasterboard, bulkhead, paint	above cupboards
CLTI-008	CEILING: plasterboard, drop-in tiles, prefinished, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWSC-011	DOOR: 1100mm c/o, single leaf, solid core, paint	Optional glazed viewing panel to door
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	Equal to Acrovyn
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	Equal to Acrovyn
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-019	WALL FINISH: vinyl, full height	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FQCW-006	BIN: waste, clinical, 240L	3	2	or waste skip
FQCW-013	BIN: waste, cytotoxic, 240L	3	1	
FQCW-017	BIN: waste, general, 240L	3	2	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	

Room Name | Disposal Room, 10m2

Room Number DISP-10

AusHFG code	Description	Group	Qty	Comment
FIDI-014	DISPENSER: disposable glove	2	1	
MMGE-143	TROLLEY: soiled linen collection	3	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELBO-015	SWITCH: light, single	1	1	