

Room Name | Disposal Room, 8m2

Room Number DISP-8

Revision 5
Issue Date 20.03.17

BRIEFING
Briefed Area 8.00 m²
Hours of Operation 24 Hours
Occupancy
Acoustics
Remarks
Description / Special Requirements

The Disposal Room provides for the temporary holding of clinical waste, general waste, sharps, soiled linen and recyclables prior to removal. The Disposal Room should be located in close proximity to a handwashing basin or be provided within the room (optional) if waste will be handled in this area. The room should be lockable.

SERVICES
General Requirements

BODY PROTECTED = No CARDIAC PROTECTED = No

Air

 AIRCONDITIONING = Yes AIRCONDITIONING: hepa filtered = No
 AIRCONDITIONING: positive pressure = No AIRCONDITIONING: negative pressure = No
 EXHAUST: room exhaust = Yes VENTILATION = No

Lighting

 LIGHTING: colour corrected = No LIGHTING: dimmable = No
 LIGHTING: downlights = No LIGHTING: downlights, dimmable = No
 LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No
 LIGHTING: fluorescent, general = Yes LIGHTING: indirect = No

Nurse Call

NURSE CALL SYSTEM = No

Room Fabrics

AusHFG code	Description	Comment
CLTI-008	CEILING: plasterboard, drop-in tiles, prefinished, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWSC-003	DOOR: 910mm c/o, single leaf, solid core, paint	lockable, optional glazed viewing panel to door
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	Default = no hand basin; to basin, if provided
WLWA-020	WALL FINISH: vinyl, to 1500 AFFL	
WLPR-013	WALL PROTECTION: corner guards, to 1500 AFFL, prefinished PVC	as required

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-011	BASIN: handwash, Type C	1	1	Default = no hand basin: optional with shroud

Room Name | Disposal Room, 8m2

Room Number DISP-8

AusHFG code	Description	Group	Qty	Comment
FQCW-006	BIN: waste, clinical, 240L	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	
FQCW-017	BIN: waste, general, 240L	3	2	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to hand basin, if provided
FIDI-030	DISPENSER: soap	2	1	to hand basin, if provided
HYTP-036	TAPWARE: mixer, basin, lever action	1	1	
MMGE-143	TROLLEY: soiled linen collection	3	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELBO-015	SWITCH: light, single	1	2	