

Room Name	Echocardiography - Transoesophageal	Room Number	ECHO-TOE
Revision	4		
Issue Date	13.05.2020		
BRIEFING			
Briefed Area	26.00 m ²		
Hours of Operation	Available 24 Hours		
Occupancy	1 patient; 1 - 2 staff		
Acoustics	Acoustic privacy is required		
Remarks			
Description / Special Requirements	Room for diagnostic echocardiography procedures including transoesophageal echocardiography. Echocardiography procedures may be performed under local anaesthesia and sedation. The Echocardiography room should be located close to patient toilet and change rooms.		
SERVICES			
General Requirements	BODY PROTECTED	<input checked="" type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
Air	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION <input type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input checked="" type="checkbox"/>	LIGHTING: dimmable <input checked="" type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
Nurse Call	NURSE CALL SYSTEM	<input checked="" type="checkbox"/>	

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWSC-021	DOOR: 1400mm c/o, 1 1/2 leaf, solid core, paint	
DWSC-003	DOOR: 910mm c/o, single leaf, solid core, paint	optional, to patient wc
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	floor finish must be minimum slip rating R10; Pendulum P3 or agreed equivalent to extend under basin
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-025	WALL FINISH: vinyl, to 1200 AFFL	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	2	patient services panel
HYBA-009	BASIN: handwash, Type A, scrub	1	1	

Room Name | Echocardiography - Transoesophageal
Room Number ECHO-TOE

AusHFG code	Description	Group	Qty	Comment
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	1	
FQSN-006	BIN: storage bins, for wall mounted panel	3	3	
FQCW-005	BIN: waste, clinical, 20L	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	to basin
FQCW-043	BIN: waste, sharps, on trolley	3	1	
FIHR-067	BRACKET: for monitor, wall mounted, articulated, adj height	2	1	
FIHR-019	BRACKET: for suction bottle	2	2	
FIJO-212	BULKHEAD: joinery	1	1	
FQBS-019	CHAIR: office, ergonomic, high	3	1	
ITCL-014	CLOCK: analogue, electric	1	1	
ITNE-071	COMPUTER: desktop, with dual display screens	3	1	
FIJO-131	CUPBOARD: tall, single door, adj shelves, lockable	1	1	
FQGE-010	CURTAIN: privacy screen	3	1	to entry door
MMHA-002	DEFIBRILLATOR	3	1	
MMMI-325	DEVICE: imaging, echocardiography machine	3	1	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-019	DISPENSER: gown/apron	2	1	
FIDI-021	DISPENSER: mask	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
MGFP-002	FLOWMETER: medical air	3	1	patient services panel
MGFP-004	FLOWMETER: oxygen	3	2	patient services panel
FIHR-026	HOOK: coat	1	2	optional
LIFX-027	LIGHT: examination, ceiling mounted	1	1	
MMGE-048	LINEN CARRIER: dirty, single	3	1	
MMGE-062	MONITOR: patient, dynamap	3	1	
FIHR-033	PANEL: for storage bins, wall mount	1	1	
FQSM-003	PEDESTAL: mobile, wire basket unit, 840H	3	2	
MMGE-088	SAFE: dangerous drugs, small	1	1	
MMGE-169	SLING: arm, dynamic, ceiling mounted	3	1	
FQBS-051	STOOL: mobile, adj height	3	1	
MMGE-100	SUCTION BOTTLE	3	2	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
ITNE-049	TELEPHONE: handset, desktop	3	1	
FIRT-025	TRACK: curtain, bedscreen, U shaped	1	1	
FQSM-016	TROLLEY	3	1	

Room Name | Echocardiography - Transoesophageal
Room Number ECHO-TOE

AusHFG code	Description	Group	Qty	Comment
MMGE-126	TROLLEY: intubation	3	1	
MMBE-069	TROLLEY: patient, echocardiography	3	1	
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	
ITCL-008	BUTTON: nurse call, staff assist	1	1	on services panel
ELGP-208	GPO: double, wall mounted	1	5	
ELGP-223	GPO: emergency power, double, wall mounted	1	3	
ELGP-122.1	GPO: emergency power, single, on services panel (V)	1	4	on services panel
ELGP-123	GPO: emergency power, single, wall mounted	1	1	
ELGP-101	GPO: single, ceiling mounted	1	1	exam light
ELGP-109	GPO: single, wall mounted	1	1	
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	5	
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	on services panel
MGAS-042	OUTLET: oxygen (O2), on services panel	1	2	on services panel
MGAS-062	OUTLET: suction, on services panel	1	2	on services panel
ELPR-006	RCD: residual current device	1	2	on services panel
MMSP-026	SERVICES PANEL: wall mounted	1	1	
ELBO-012	SWITCH: light, dimmer	1	1	
ELBO-015	SWITCH: light, single	1	2	1 optional, to optional clean up room