

Room Name | Equipment Clean-Up, 10m2
Room Number ECL-10
Revision 5
Issue Date 20.03.17

BRIEFING
Briefed Area 10.00 m²
Hours of Operation 24 Hours
Occupancy 1 - 2

Acoustics
Remarks
Description / Special Requirements

The Equipment Clean-Up Room is used for cleaning and maintaining of equipment used in the Unit. Storage may be required for holding cleaned equipment and spares. Equipment may also be recharged in this room. Natural light is desirable.

SERVICES
General Requirements

BODY PROTECTED = No

CARDIAC PROTECTED = No

Air

 AIRCONDITIONING = No
 AIRCONDITIONING: positive pressure = No
 EXHAUST: room exhaust = Yes

 AIRCONDITIONING: hepa filtered = No
 AIRCONDITIONING: negative pressure = No
 VENTILATION = Yes

Lighting

 LIGHTING: colour corrected = No
 LIGHTING: downlights = No
 LIGHTING: fluorescent, downlights = No
 LIGHTING: fluorescent, general = Yes

 LIGHTING: dimmable = No
 LIGHTING: downlights, dimmable = No
 LIGHTING: fluorescent, flush with ceiling, tamper proof = No
 LIGHTING: indirect = No

Nurse Call

NURSE CALL SYSTEM = No

Room Fabrics

AusHFG code	Description	Comment
CLFS-009	CEILING: plasterboard, water resistant, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-020	DOOR: 1100mm c/o, single leaf, observation panel, solid core/glass, paint	1100mm clear opening, lockable
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	Equal to Acrovyn
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	Equal to Acrovyn
FLVY-004	FLOOR FINISH: vinyl, seamless, coved, non-slip, safety	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-020	WALL FINISH: vinyl, to 1500 AFFL	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	Refer to BHWS-B (similar)
FIJO-021	BENCH: 600D, open under, stainless steel lipped	1	1	Wet edge, inset sink
FQCW-016	BIN: waste, general, 20L	3	2	to basin and under bench
FIJO-124	CUPBOARD: tall, triple door, adj shelves, lockable	1	1	optional
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	1	over bench

Room Name | **Equipment Clean-Up, 10m2**
Room Number ECL-10

AusHFG code	Description	Group	Qty	Comment
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	
HYTP-004	HOSE: spray	1	1	optional
FIJO-197	SHELF: stainless steel, underbench	1	1	under bench
HYBA-055	SINK: single, 500 x 450 x 250D	1	2	hot water
HYTP-037	TAPWARE: mixer, elbow levers	1	2	to sinks
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
FQSM-016	TROLLEY	3	2	optional

Engineering Services

AusHFG code	Description	Group	Qty	Comment
HYDR-004	DRAIN: floor waste	1	1	
ELGP-208	GPO: double, wall mounted	1	2	
ELBO-015	SWITCH: light, single	1	1	