# Australasian Health Facility Guidelines

Room Name	Equipment Clean-Up, 14m2	Room Number ECL-14
Revision	5	
Issue Date	20.03.17	
BRIEFING		
Briefed Area	14.00 m <sup>2</sup>	
Hours of Operation	24 Hours	
Occupancy	1 - 2	
Acoustics		
Remarks		
Description / Special Requirements		eaning and maintaining of equipment used in the Unit. Storage t and spares. Equipment may also be recharged in this room.
SERVICES		
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No
Air	AIRCONDITIONING = No	AIRCONDITIONING: hepa filtered = No
	AIRCONDITIONING: positive pressure = No	AIRCONDITIONING: negative pressure = No
	EXHAUST: room exhaust = Yes	VENTILATION = Yes
Lighting	LIGHTING: colour corrected = No	LIGHTING: dimmable = No
	LIGHTING: downlights = No	LIGHTING: downlights, dimmable = No
	LIGHTING: fluorescent, downlights = No	LIGHTING: fluorescent, flush with ceiling, tamper proof = N
	LIGHTING: fluorescent, general = Yes	LIGHTING: indirect = No
	NURSE CALL SYSTEM = No	

### **Room Fabrics**

AusHFG code	Description	Comment
CLFS-009	CEILING: plasterboard, water resistant, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-020	DOOR: 1100mm c/o, single leaf, observation panel, solid core/glass, paint	lockable
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	Equal to Acrovyn
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	Equal to Acrovyn
FLVY-004	FLOOR FINISH: vinyl, seamless, coved, non-slip, safety	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-020	WALL FINISH: vinyl, to 1500 AFFL	

## Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	Refer BHWS-B (similar). Elbow action levers or handsfree optional.
FIJO-021	BENCH: 600D, open under, stainless steel lipped	1	1	wet edge, inset sinks
FQCW-016	BIN: waste, general, 20L	3	2	to basin and under bench
FIJO-117	CUPBOARD: tall, double door, adj shelves, lockable	1	2	optional





#### Room Name Equipment Clean-Up, 14m2

Room Number ECL-14

AusHFG code	Description	Group	Qty	Comment
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	1	over bench
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	
HYTP-004	HOSE: spray	1	1	optional
FIJO-197	SHELF: stainless steel, underbench	1	1	under bench
HYBA-055	SINK: single, 500 x 450 x 250D	1	2	hot water
HYTP-037	TAPWARE: mixer, elbow levers	1	2	to sinks
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin. Elbow action levers or handsfree optional.
MMGE-119	TROLLEY: equipment	3	3	optional
MMIC-097	WASHER SANITISER: utensil washer	1	1	optional

## **Engineering Services**

AusHFG code	Description	Group	Qty	Comment
HYDR-004	DRAIN: floor waste	1	1	
ELGP-208	GPO: double, wall mounted	1	2	
ELGP-106	GPO: single, special, for equipment	1	1	utensil washer, optional
ELPR-003	ISOLATOR: electrical, 1ph+n	1	1	
HYTP-008	OUTLET: cold water	1	1	
HYTP-013	OUTLET: hot water	1	1	
ELBO-015	SWITCH: light, single	1	1	