



Room Name	Equipment Clean-Up, 8m2	Room Number ECL-8				
Revision	5					
Issue Date	20.03.17					
BRIEFING						
Briefed Area	8.00 m <sup>2</sup>					
Hours of Operation	24 Hours					
Occupancy	1 - 2					
Acoustics						
Remarks						
Description / Special Requirements	The Equipment Clean-Up Room is used for cleaning and maintaining of equipment used in the Unit. Storage may be required for holding cleaned equipment and spares. Equipment may also be recharged in this room. Natural light is desirable.					
SERVICES						
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No				
Air	AIRCONDITIONING = No AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = Yes	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = Yes				
Lighting	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No				
Nurse Call	NURSE CALL SYSTEM = No					

## **Room Fabrics**

AusHFG code	Description	Comment
CLFS-009	CEILING: plasterboard, water resistant, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-020	DOOR: 1100mm c/o, single leaf, observation panel, solid core/glass, paint	lockable
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	Equal to Acrovyn
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	Equal to Acrovyn
FLVY-004	FLOOR FINISH: vinyl, seamless, coved, non-slip, safety	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-020	WALL FINISH: vinyl, to 1500 AFFL	

## Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	Refer BHWS-B (similar)
FIJO-021	BENCH: 600D, open under, stainless steel lipped	1	1	wet edge, inset sink
FQCW-016	BIN: waste, general, 20L	3	1	
FIJO-117	CUPBOARD: tall, double door, adj shelves, lockable	1	1	optional
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	1	over bench

Page: 1 Print Date: 20/03/2017







**Room Name** 

Equipment Clean-Up, 8m2

## **Room Number ECL-8**

AusHFG code	Description	Group	Qty	Comment
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	
FIJO-197	SHELF: stainless steel, underbench	1	1	under bench
HYBA-055	SINK: single, 500 x 450 x 250D	1	2	hot water
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
HYTP-037	TAPWARE: mixer, elbow levers	1	2	to sinks

## **Engineering Services**

AusHFG code	Description	Group	Qty	Comment
HYDR-004	DRAIN: floor waste	1	1	
ELGP-208	GPO: double, wall mounted	1	2	
ELBO-015	SWITCH: light, single	1	1	



Page: 2 Print Date: 20/03/2017