

Room Name	Ensuite - Bariatric, 7m2		Room Number ENS-BA
<b>Revision</b>	2		
<b>Issue Date</b>	20.03.17		
<b>BRIEFING</b>			
<b>Briefed Area</b>	7.00 m <sup>2</sup>		
<b>Hours of Operation</b>	24 Hours		
<b>Occupancy</b>	1 patient; 1-2 staff assisting		
<b>Acoustics</b>	Sound attenuation level high, Acoustic privacy is required.		
<b>Remarks</b>			
<b>Description / Special Requirements</b>	<p>An Ensuite - Bariatric is designed to meet the needs of bariatric (obese or morbidly obese) patients allowing the patient to wash, shave, groom themselves, shower and use the toilet, either independently or with assistance. The Ensuite - Bariatric is associated with the 1 Bed Room - Bariatric. The area and layout must accommodate two assisting nurses and a shower commode with bariatric capability. The Ensuite and Bedroom will need to be planned as an integral suite so the use of a ceiling mounted hoist is optimised across the two rooms. The choice of Ensuite will depend on the patient type, the Operational Policy and floor layout of the facility. Additional Design Requirements: The shower floor must not have a raised hob. The entrance is to be flush with the adjoining flooring. The door is to be fitted with escape hardware.</p>		
<b>SERVICES</b>			
<b>General Requirements</b>	BODY PROTECTED = Yes	CARDIAC PROTECTED = No	
<b>Air</b>	AIRCONDITIONING = No AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = Yes	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = Yes	
<b>Lighting</b>	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No	
<b>Nurse Call</b>	NURSE CALL SYSTEM = Yes		

**Room Fabrics**

AusHFG code	Description	Comment
CLTI-014	CEILING: plasterboard, water resistant, drop-in tiles, prefinished, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWSC-012	DOOR: 1200mm c/o, 1 1/2 leaf, solid core, paint	outward opening, privacy latch, emergency release
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	
FLVY-009	FLOOR FINISH: vinyl, seamless, coved, wet area, non-slip	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	or tiles for a tiled floor
WLWA-004	WALL FINISH: paint, acrylic, washable	for any areas not covered with vinyl/tile
WLWA-019	WALL FINISH: vinyl, full height	to wet areas; tiles also acceptable

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
HYBA-002	BASIN: ensuite, with vanity unit	1	1	

**Room Name** | **Ensuite - Bariatric, 7m2**
**Room Number ENS-BA**

AusHFG code	Description	Group	Qty	Comment
FQCW-016	BIN: waste, general, 20L	3	1	
FQCW-037	BIN: waste, sanitary	3	1	
MMGE-025	CHAIR: shower, bariatric	3	1	
FQGE-011	CURTAIN: shower	3	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	optional
FIDI-030	DISPENSER: soap	2	2	optional
FIDI-036	DISPENSER: toilet paper	1	1	
FIRT-003	GRAB RAIL: shower, horizontal	1	1	
FIRT-008	GRAB RAIL: WC, hinged	1	2	optional
FIDI-051	HOLDER: soap/shampoo, recessed, vertical format	1	1	
FIHR-026	HOOK: coat	1	2	1 @ 1200 AFFL for wheelchair users
MMBE-061	LIFTER: patient, ceiling mounted, track, traverse, bariatric	1	1	
FIBM-006	MIRROR: fixed, glass	1	1	over basin
FIRT-016	RAIL: towel	1	1	
HYTP-020	SHOWER: hand-held	1	1	
HYTP-036	TAPWARE: mixer, basin, lever action	1	1	
HYTP-039	TAPWARE: mixer, shower, lever action	1	1	
HYWC-002	TOILET SUITE: bariatric	1	1	
FIRT-034	TRACK: curtain, shower, 90 deg	1	1	

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	2	+ indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	
HYDR-004	DRAIN: floor waste	1	2	1 near wc/basin, 1 for shower
ELGP-208	GPO: double, wall mounted	1	1	
MGAS-043	OUTLET: oxygen (O2), wall mounted	1	1	optional
ITCL-031	PENDANT: nurse call, patient to staff	1	1	waterproof
ELBO-015	SWITCH: light, single	1	1	