

**Room Name** | **Ensuite - Mental Health, Inboard, 5m2**
**Room Number** **ENS-MH-A**
**Revision** | 4  
**Issue Date** | 02.07.2018

**BRIEFING**
**Briefed Area** | 5.00 m<sup>2</sup>  
**Hours of Operation** | 24 Hours  
**Occupancy** | 1 patient; 1 staff assisting as required  
**Acoustics** | Sound attenuation level high, Acoustic privacy is required.

**Remarks**
**Description /  
Special Requirements**

The Ensuite - Mental Health will provide a shower, toilet and handbasin for use by patients in a mental health inpatient unit. The Ensuite will be lockable and master keyed from the outside. All fittings and fixtures used in consumer areas of the building must be of a type manufactured and marketed as anti-ligature; and installed in accordance with the manufacturer's instructions. Door and joinery hardware and any engineering services outlets must not provide ligature points and must be tamper proof. Selected fixtures are to have a breaking strain of not more than 15kg (e.g. shower curtain rail). Consider location of wi-fi access points to ensure strong wi-fi coverage is provided for mobile duress functions. Jurisdictional policy to be read in conjunction with guidelines.

**SERVICES**
**General Requirements**

BODY PROTECTED	<input checked="" type="checkbox"/>	CARDIAC PROTECTED	<input type="checkbox"/>
----------------	-------------------------------------	-------------------	--------------------------

**Air**

AIRCONDITIONING	<input type="checkbox"/>	AIRCONDITIONING: hepa filtered	<input type="checkbox"/>
AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure	<input type="checkbox"/>
EXHAUST: room exhaust	<input checked="" type="checkbox"/>	VENTILATION	<input checked="" type="checkbox"/>

**Lighting**

LIGHTING: colour corrected	<input type="checkbox"/>	LIGHTING: dimmable	<input type="checkbox"/>
LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable	<input type="checkbox"/>
LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof	<input checked="" type="checkbox"/>
LIGHTING: fluorescent/LED, general	<input type="checkbox"/>	LIGHTING: indirect	<input type="checkbox"/>

**Nurse Call**

NURSE CALL SYSTEM	<input checked="" type="checkbox"/>
-------------------	-------------------------------------

**Room Fabrics**

AusHFG code	Description	Comment
CLFS-009	CEILING: plasterboard, water resistant, flush set, suspended, paint, washable	for High Dependency and intensive care areas, consider plywood or equivalent backing to ceiling finish
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWSC-004	DOOR: 850mm c/o, 180 deg swing, single leaf, solid core, paint	door swing outward and anti ligature hardware
FLVY-009	FLOOR FINISH: vinyl, seamless, coved, wet area, non-slip	tiles also acceptable
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	or tiles for a tiled floor
WLWA-019	WALL FINISH: vinyl, full height	tiles also acceptable

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
HYBA-078	BASIN: with integrated shelf	1	1	
FQCW-016	BIN: waste, general, 20L	3	1	to basin
FQCW-037	BIN: waste, sanitary	3	1	

**Room Name** | **Ensuite - Mental Health, Inboard, 5m2**
**Room Number ENS-MH-A**

AusHFG code	Description	Group	Qty	Comment
FQGE-011	CURTAIN: shower	3	1	optional, collapsible; anti ligature fabric; dependent on jurisdictional policy
FIDI-038	DISPENSER: toilet paper, recessed	1	1	recessed or with 15kg breaking strength if wall mounted
HYTP-002	FLUSH BUTTON: toilet suite	1	1	
FIRT-004	GRAB RAIL: shower, anti ligature	1	1	optional, vertical
FIRT-009	GRAB RAIL: WC, anti ligature	1	1	optional, vertical
FIDI-051	HOLDER: soap/shampoo, recessed, vertical format	1	1	to shower
FIHR-027	HOOK: coat, collapsible, anti ligature	1	2	one at 1200AFFL for wheelchair users; dependent on jurisdictional policy
FIBM-022	MIRROR: fixed, safety glass, toughened and laminated, anti ligature	1	1	optional; glued to backing material and screw fixed. some jurisdictions may require material to be polycarbonate
HYTP-019	SHOWER: fixed rose, anti ligature	1	1	
HYTP-024	SPOUT: basin, anti ligature	1	1	
HYTP-047	TAPWARE: hot and cold taps, basin, anti ligature	1	1	
HYTP-046	TAPWARE: hot and cold taps, shower, anti ligature	1	1	
HYWC-005	TOILET SUITE: concealed cistern, floor mounted	1	1	accessible height for patient use
FIRT-029	TRACK: curtain, plastic, recessed	1	1	optional, for privacy screen to shower area; dependent on jurisdictional policy. 15kg breaking strength recommended

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ITCL-006	BUTTON: nurse call, patient to staff	1	2	optional, + indicator button & light
HYDR-011	DRAIN: clear out, anti ligature	1	1	
HYDR-010	DRAIN: floor waste, anti ligature	1	2	
ITSE-045	SENSOR: motion detection, for lighting control, flush to ceiling	1	1	optional
ELBO-015	SWITCH: light, single	1	1	outside door. may optionally be replaced with light motion sensor deactivation switch