

Room Name	Fluoroscopy Control Room		Room Number FLUOC
<b>Revision</b>	1		
<b>Issue Date</b>	29.05.2019		
<b>BRIEFING</b>			
<b>Briefed Area</b>	12.00 m <sup>2</sup>		
<b>Hours of Operation</b>	Available 24 hours		
<b>Occupancy</b>	Up to 2 staff		
<b>Acoustics</b>	Acoustic privacy is required		
<b>Remarks</b>			
<b>Description / Special Requirements</b>	Room adjacent to the Fluoroscopy Room with direct visibility to the patient for remote control of equipment, and review and reporting of procedure images. Additional Design Considerations: Radiation shielding as advised by radiation consultant. Cable ducts from the imaging and equipment room will be required.		
<b>SERVICES</b>			
<b>General Requirements</b>	BODY PROTECTED	<input type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
<b>Air</b>	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION <input type="checkbox"/>
<b>Lighting</b>	LIGHTING: colour corrected	<input type="checkbox"/>	LIGHTING: dimmable <input checked="" type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
<b>Nurse Call</b>	NURSE CALL SYSTEM	<input checked="" type="checkbox"/>	

**Room Fabrics**

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	
DWSC-005	DOOR: 910mm c/o, single leaf, solid core, lead shielding, paint	
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
DWOB-009	OBSERVATION: internal window, lead glass, clear	safety glass
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
FIJO-031	BENCH: 750D, open under, laminate finish	1	2	high bench at 900-950 AFFL optional
FQCW-016	BIN: waste, general, 20L	3	1	

**Room Name | Fluoroscopy Control Room**
**Room Number FLUOC**

AusHFG code	Description	Group	Qty	Comment
DWWD-004	BLIND: roller	3	1	to observation window for patient privacy
FIHR-075	BRACKET: for computer CPU, underdesk mounted	2	2	
FIHR-076	BRACKET: for display screen, triple, desk mounted	3	1	
FIHR-066	BRACKET: for display screen, wall mounted, articulated, adj height	2	1	
FQSN-031	CABINET: short, single door, tambour, adj shelves, lockable	3	1	
FIJO-099	CAC: cable access cap	3	2	
FQBS-018	CHAIR: office, ergonomic	3	2	
MMMI-115	COMPUTER: CPU, fluoroscopy	1	1	
ITNE-068	COMPUTER: hi performance, for clinical / PACS use, CPU, underbench mount	3	1	
MMMI-117	CONSOLE: control, fluoroscopy/screening	1	1	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
ITNE-063	DISPLAY SCREEN: for computer	3	1	
ITNE-069	DISPLAY SCREEN: PACS, portrait	3	2	
MMGE-032	DISPLAY SCREEN: slave, for patient monitor	3	1	
FQCA-038	FRIDGE: domestic, underbench, 80L	3	1	optional, with temperature alarm
FIHR-026	HOOK: coat	1	2	optional
ITNE-067	KEYBOARD: keyboard and mouse only	3	1	
ITAV-014	MICROPHONE: surface mounted, gooseneck	2	1	communication with patient, on bench required if integrated intercom system not provided by equipment manufacturer
FIHR-044	RACK: lead apron	1	1	
ITNE-049	TELEPHONE: handset, desktop	3	1	
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ELBO-001	BUTTON: emergency stop	1	1	main power emergency stop, consult equipment manufacturer for safety and compatibility with equipment.
ITCL-004	BUTTON: nurse call, emergency	1	1	
ELGP-208	GPO: double, wall mounted	1	1	
ELGP-223	GPO: emergency power, double, wall mounted	1	4	
ELGP-123.1	GPO: emergency power, single, wall mounted (V)	1	1	
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ELGP-135	GPO: UPS, single, wall mounted	1	5	
ITSE-028	INTERCOM: audiovisual, wall mounted	1	1	to screening room bed entry door
LIFX-002	LIGHT: illuminated sign, "X-Ray in Use"	1	1	auto on when modality is in use
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	

Room Name | Fluoroscopy Control Room

Room Number FLUOC

AusHFG code	Description	Group	Qty	Comment
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	2	1 outlet for slave display screen, one outlet for telephone
WLSH-004	SHIELDING: lead lining	1	1	to radiation consultant specification
ELBO-012	SWITCH: light, dimmer	1	2	