

Room Name	Formula Room		Room Number FORM
Revision	3		
Issue Date	20.03.17		
BRIEFING			
Briefed Area	7.00 m ²		
Hours of Operation	24 Hours		
Occupancy	1 - 2		
Acoustics	Acoustic privacy is required		
Remarks			
Description / Special Requirements	The Formula Room provides space for the preparation, distribution and storage of baby feeds. Pre-packaged feeds will also be stored in this area. The room will provide facilities for washing, sterilisation and storage of baby bottles, teats and equipment, preparation of baby formulas, refrigerated storage of baby feeds and demonstration of formula preparation to mothers.		
SERVICES			
General Requirements	BODY PROTECTED = Yes	CARDIAC PROTECTED = No	
Air	AIRCONDITIONING = Yes	AIRCONDITIONING: hepa filtered = No	
	AIRCONDITIONING: positive pressure = No	AIRCONDITIONING: negative pressure = No	
	EXHAUST: room exhaust = No	VENTILATION = No	
Lighting	LIGHTING: colour corrected = No	LIGHTING: dimmable = No	
	LIGHTING: downlights = No	LIGHTING: downlights, dimmable = No	
	LIGHTING: fluorescent, downlights = No	LIGHTING: fluorescent, flush with ceiling, tamper proof = No	
	LIGHTING: fluorescent, general = Yes	LIGHTING: indirect = No	
Nurse Call	NURSE CALL SYSTEM = No		

RETIRED

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	with hold open device
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	equal to Acrovyn
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	equal to Acrovyn
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
DWOB-002	OBSERVATION: internal window, alum/glass, door height, powdercoat	observation window to Nursery area
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	tiles also acceptable

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	1	with inset sink
FQCW-016	BIN: waste, general, 20L	3	1	
FIJO-106	CUPBOARD: drawer unit, 4 equal	1	1	under bench

Room Name | Formula Room

Room Number FORM

AusHFG code	Description	Group	Qty	Comment
FIJO-135	CUPBOARD: underbench, double door, adj shelves	1	1	
FIJO-140	CUPBOARD: underbench, single door, adj shelves	1	1	
FIJO-143	CUPBOARD: wall mount, double door, adj shelves	1	2	over bench
FIJO-207	CUPBOARD: wall mount, shelf unit, adj shelves for microwave, short	1	1	over bench, optional
FQCA-009	DISHWASHER: commercial	2	1	under bench, optional
FIDI-025	DISPENSER: paper/hand towel	2	1	to sink
FIDI-030	DISPENSER: soap	2	1	to sink
FQCA-031	FRIDGE: domestic, 250L	3	1	
FQCA-046	KETTLE: electric	3	1	
HYBA-069	SINK: single, with drainer, 930mmL	1	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELGP-209	GPO: double, wall mounted, RCD protected	1	1	
ELGP-106	GPO: single, special, for equipment	1	3	BWU, fridge, microwave
ELGP-109	GPO: single, wall mounted	1	5	
LIFX-008	LIGHT: task light, built in	1	2	
ELBO-015	SWITCH: light, single	1	2	

RETIRED