

Room Name	Film Processing, Viewing and Reporting	Room Number FPVR
Revision	3	
Issue Date	20.03.17	
BRIEFING		
Briefed Area	16.00 m ²	
Hours of Operation	8am to 8pm, daily	
Occupancy	Up to 4	
Acoustics	Sound attenuation level medium, Acoustic privacy is required.	
Remarks		
Description / Special Requirements	A room located within the Medical Imaging Unit to accommodate the film processing equipment along with a workstation area for viewing, and reporting of images.	
SERVICES		
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No
Lighting	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = Yes LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No
Nurse Call	NURSE CALL SYSTEM = No	

RETIRED

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	glazing optional
DWPR-003	DOOR PROTECTION: kickplate, to 300 AFFL, vinyl, prefinished	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	above sink, tiles also acceptable

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FIJO-031	BENCH: 750D, open under, laminate finish	1	1	workstation bench
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	1	with inset sink
FQCW-016	BIN: waste, general, 20L	3	1	
MMLA-026	CABINET: hazardous goods, small	3	1	chemical storage
FQBS-018	CHAIR: office, ergonomic	3	2	
FQGE-005	CLOCK: analogue, battery operated	3	1	

Room Name | Film Processing, Viewing and Reporting
Room Number FPVR

AusHFG code	Description	Group	Qty	Comment
ITNE-009	COMPUTER: hi performance, for clinical / PACS use	3	2	
FIJO-135	CUPBOARD: underbench, double door, adj shelves	1	2	
FIJO-143	CUPBOARD: wall mount, double door, adj shelves	1	2	over sink bench
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	5	over workstation bench
MMMI-331	DEVICE: imaging, silver recovery unit	3	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to sink
FIDI-030	DISPENSER: soap	2	1	to sink
FIBM-013	NOTICEBOARD: fixed, fabric covered	1	2	above bench
WLPT-003	PARTITION: laminate	1	2	under bench, as required
FQSM-007	PEDESTAL: mobile, drawer unit, 660H	3	1	
ITNE-023	PRINTER: networked	3	1	
MMMI-344	PROCESSOR: imaging, daylight	3	1	
HYBA-060	SINK: single, 600 x 450 x 450D	1	1	hot water, lab sink
HYTP-037	TAPWARE: mixer, elbow levers	1	1	
ITNE-049	TELEPHONE: handset, desktop	3	2	
MMGE-155	VIEWER: X-ray, (4) multiscreen	1	2	optional

Engineering Services

RETIRED

AusHFG code	Description	Group	Qty	Comment
HYDR-006	DRAIN: tundish			
ELGP-208	GPO: double, wall mounted	1	5	2 per workstation + 1- printer
ELGP-106	GPO: single, special, for equipment	1	2	Processor, XRV
LIFX-008	LIGHT: task light, built in	1	4	under O/H shelving
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	4	2 outlets on workstation bench side for telephone
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	to printer, processor
ELBO-015	SWITCH: light, single	1	1	for built-in task lights
ELBO-015	SWITCH: light, single	1	1	