



| Room Name                             | Gymnasium, Individual Treatment  | Room Number GYAH-ID         | Room Number GYAH-ID  |     |  |
|---------------------------------------|--|-----------------------------|--|-----|--|
| Revision                              | 1  |                             |  |     |  |
| Issue Date                            | 26.04.2021   |                             |  |     |  |
| BRIEFING                              |  |                             |  |     |  |
| Briefed Area                          | 76.00 m <sup>2</sup>   |                             |  |     |  |
| Hours of Operation                    | 7am to 6pm daily   |                             |  |     |  |
| Occupancy                             | up to 8 patients, 3 staff  |                             |  |     |  |
| Acoustics                             | Acoustic privacy is required   |                             |  |     |  |
| Remarks                               | · ·  |                             |  |     |  |
| Description /<br>Special Requirements | therapy and ambulation training. A num   | ber o<br>quipr              | des space and facilities for one on one patient evaluation, f curtained bays with plinths are typically provided along wit nent such as stairs, parallel bars and exercise bikes. An extensional desirable.  |     |  |
|                                       |  |                             |  |     |  |
|                                       |  |                             | , open exercise areas and number of clients / patients to be from unit to unit and will require confirmation to inform over  |     |  |
|                                       | accommodated within a gymnasium wi   |                             |  |     |  |
|                                       | accommodated within a gymnasium wi<br>space requirements.<br>Additional Design Requirements:   | ll vary                     | from unit to unit and will require confirmation to inform over   | all |  |
|                                       | accommodated within a gymnasium wi<br>space requirements.  Additional Design Requirements:  RCD protection is require  | II vary                     |  | all |  |
| SERVICES                              | accommodated within a gymnasium wi<br>space requirements.  Additional Design Requirements:  RCD protection is require  | II vary                     | from unit to unit and will require confirmation to inform over ody protected areas in accordance with AS/NZS3003. Quar   | all |  |
| SERVICES<br>Electrical                | accommodated within a gymnasium wi<br>space requirements.  Additional Design Requirements:  RCD protection is require  | II vary                     | from unit to unit and will require confirmation to inform over ody protected areas in accordance with AS/NZS3003. Quar   | all |  |
|                                       | accommodated within a gymnasium wi<br>space requirements.  Additional Design Requirements:  RCD protection is require<br>and location dependent o  | ll vary<br>d to b<br>n sele | from unit to unit and will require confirmation to inform over ody protected areas in accordance with AS/NZS3003. Quarticted equipment and circuiting arrangements.  | all |  |
| Electrical                            | accommodated within a gymnasium wi<br>space requirements.  Additional Design Requirements:  RCD protection is require<br>and location dependent o  | d to b                      | from unit to unit and will require confirmation to inform over ody protected areas in accordance with AS/NZS3003. Quarticled equipment and circuiting arrangements.  CARDIAC PROTECTED  AIRCONDITIONING: hepa filtered   | all |  |
| Electrical                            | accommodated within a gymnasium wi<br>space requirements.  Additional Design Requirements:  RCD protection is require<br>and location dependent o  | d to b                      | from unit to unit and will require confirmation to inform over ody protected areas in accordance with AS/NZS3003. Quarticled equipment and circuiting arrangements.  CARDIAC PROTECTED   | all |  |
| Electrical                            | accommodated within a gymnasium wi space requirements.  Additional Design Requirements:  RCD protection is require and location dependent of the space and location dependent  | d to b                      | from unit to unit and will require confirmation to inform over ody protected areas in accordance with AS/NZS3003. Quarted equipment and circuiting arrangements.  CARDIAC PROTECTED  AIRCONDITIONING: hepa filtered AIRCONDITIONING: negative pressure   | all |  |
| Electrical<br>HVAC                    | accommodated within a gymnasium wi space requirements.  Additional Design Requirements:  RCD protection is require and location dependent of the space and location dependent  | d to b                      | from unit to unit and will require confirmation to inform over ody protected areas in accordance with AS/NZS3003. Quarticled equipment and circuiting arrangements.  CARDIAC PROTECTED  AIRCONDITIONING: hepa filtered AIRCONDITIONING: negative pressure VENTILATION  | all |  |
| Electrical<br>HVAC                    | accommodated within a gymnasium wi space requirements.  Additional Design Requirements:  RCD protection is require and location dependent of the space and location dependent  | d to b                      | ody protected areas in accordance with AS/NZS3003. Quarticled equipment and circuiting arrangements.  CARDIAC PROTECTED  AIRCONDITIONING: hepa filtered AIRCONDITIONING: negative pressure VENTILATION  LIGHTING: dimmable   | all |  |
| Electrical<br>HVAC                    | accommodated within a gymnasium wi space requirements.  Additional Design Requirements:  RCD protection is require and location dependent of the space of the spa | d to b                      | rom unit to unit and will require confirmation to inform over ody protected areas in accordance with AS/NZS3003. Quarted equipment and circuiting arrangements.  CARDIAC PROTECTED  AIRCONDITIONING: hepa filtered AIRCONDITIONING: negative pressure VENTILATION  LIGHTING: dimmable LIGHTING: downlights, dimmable LIGHTING: fluorescent/LED, flush with ceiling, tamper | all |  |

## **Room Fabrics**

| AusHFG code | Description  | Comment                      |
|-------------|--|------------------------------|
| CLTI-008    | CEILING: plasterboard, drop-in tiles, prefinished, 600 x 1200      |                              |
| CLCN-009    | CORNICE: wall trim fixing  |                              |
| DWGL-041    | DOOR: 1500mm c/o, 1 1/2 leaf, half glazed, solid core/glass, paint |                              |
| DWSC-027    | DOOR: 1600mm c/o, 1 1/2 leaf, solid core, paint                    | optional, to equipment store |
| DWPR-005    | DOOR PROTECTION: protection plate to 900 AFFL                      |                              |
| FLVY-007    | FLOOR FINISH: vinyl, seamless, coved, standard slip resistant      |                              |
| FLVY-010    | FLOOR FINISH: vinyl, seamless, inset floor markings                |                              |
| FLSK-010    | SKIRTING: vinyl, floor vinyl coved, 150H, prefinished              |                              |
| WLWA-004    | WALL FINISH: paint, acrylic, washable                              |                              |
| WLWA-020    | WALL FINISH: vinyl, to 1500 AFFL                                   |                              |

australasian bealth infrastructure alliance

Page: 1 Print Date: 25/04/2021





Room Name

**Gymnasium, Individual Treatment** 

**Room Number GYAH-ID** 

## Fittings, Furniture and Equipment (FF&E) Items

| AusHFG code | Description  | Group | Qty | Comment  |
|-------------|--|-------|-----|--|
| MMAH-001    | BARS: parallel                                     | 3     | 1   | bariatric capacity to be determine based on service requirements |
| MMAH-002    | BICYCLE: exercise                                  | 3     | 1   |  |
| FQSN-007    | BIN: storage bins, wire mesh, stainless steel      | 1     | 3   | to plinths   |
| FIJO-212    | BULKHEAD: joinery                                  | 1     | 1   | plasterboard bulkhead also<br>acceptable                         |
| FQGE-005    | CLOCK: analogue, battery operated                  | 3     | 1   |  |
| ITNE-008    | COMPUTER: for workstation on wheels                | 3     | 3   |  |
| FIJO-227    | CUPBOARD: tall, double door, gym equipment storage | 1     | 1   |  |
| FQGE-010    | CURTAIN: privacy screen                            | 3     | 3   | to plinths   |
| FIDI-001    | DISPENSER: alcohol based hand rub                  | 2     | 4   |  |
| FIHR-029    | HOOK: equipment                                    | 1     | 6   | to plinths   |
| FIBM-010    | MIRROR: fixed, safety glass, full length           | 1     | 1   |  |
| FIHR-033    | PANEL: for storage bins, wall mount                | 1     | 3   | to plinths   |
| MMAH-033    | PLINTH: double width                               | 3     | 1   |  |
| MMAH-035    | PLINTH: single width                               | 3     | 2   |  |
| FIHR-061    | RACK: weights                                      | 3     | 1   |  |
| MMAH-044    | STAIRS: exercise, 90 degree                        | 3     | 1   |  |
| FIRT-017    | STEEL MESH: framed, ceiling mount                  | 1     | 3   | optional, to plinths   |
| ITNE-053    | TELEPHONE: handset, wall mount, handsfree          | 3     | 1   |  |
| FIRT-032    | TRACK: curtain, privacy, L shaped                  | 1     | 3   |  |
| MMAH-027    | TREADMILL: automatic                               | 3     | 1   |  |
| MMGE-164    | WORKSTATION ON WHEELS: clinical, mobile            | 3     | 3   |  |

## **Engineering Services**

| AusHFG code | Description  | Group | Qty | Comment                                 |
|-------------|--|-------|-----|---|
| ITCL-004    | BUTTON: nurse call, emergency                          | 1     | 4   | 3 x to plinth, 1 x at entry door        |
| ITCL-008    | BUTTON: nurse call, staff assist                       | 1     | 4   | 3 x to plinth, 1 x at entry door        |
| ELGP-208    | GPO: double, wall mounted                              | 1     | 9   | to plinths                              |
| ELGP-208    | GPO: double, wall mounted                              | 1     | 3   | quantity to suit equipment requirements |
| ELGP-109    | GPO: single, wall mounted                              | 1     | 3   | to plinths                              |
| ELGP-110    | GPO: single, wall mounted, cleaner                     | 1     | 1   |   |
| ITCL-028    | HANDSET: nurse call, with patient to staff call button | 1     | 3   | optional, to plinths                    |
| ITIN-026    | OUTLET: data, double RJ45, wall mounted                | 1     | 3   | to plinths                              |
| ITIN-016    | OUTLET: data, single RJ45, wall mounted                | 1     | 1   | to telephone                            |
| ELBO-015    | SWITCH: light, single                                  | 1     | 1   |   |

Page: 2