

Room Name	Interview Room - Mental Health		Room Number INTF-MH
<b>Revision</b>	1		
<b>Issue Date</b>	02.07.2018		
<b>BRIEFING</b>			
<b>Briefed Area</b>	14.00 m <sup>2</sup>		
<b>Hours of Operation</b>	Varies		
<b>Occupancy</b>	1 Patient; 1-2 staff; 1-2 visitors		
<b>Acoustics</b>	Sound attenuation high; acoustic privacy is required		
<b>Remarks</b>			
<b>Description / Special Requirements</b>	<p>The Interview Room - Mental Health provides a room that can be used by patients with mental health conditions for interviews or counselling. The room has been configured to reduce risks to both staff and patients. A secondary egress door is shown. All fittings must be of a type manufactured as anti ligature and installed in accordance with manufacturer's instructions. Door and joinery hardware and any engineering services outlets must not provide ligature points and must be tamper proof. All glass must be Grade A safety glass to comply with AS1288 and AS/ANZ 2208, specifically toughened laminated glass of min. 14.28mm thickness or equivalent approved. Consider location of wi-fi access points to ensure strong wi-fi coverage is provided for mobile duress functions. Jurisdictional policy to be read in conjunction with guidelines.</p>		
<b>SERVICES</b>			
<b>General Requirements</b>	BODY PROTECTED	<input checked="" type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
<b>Air</b>	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION <input type="checkbox"/>
<b>Lighting</b>	LIGHTING: colour corrected	<input type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input checked="" type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
<b>Nurse Call</b>	NURSE CALL SYSTEM	<input type="checkbox"/>	

**Room Fabrics**

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWGL-007	DOOR: 910mm c/o, single leaf, observation panel, solid core/safety glass, paint	privacy film to be applied to obs panel in second egress door
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	optional
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional
FLCP-006	FLOOR FINISH: carpet, carpet tiles, 90/10 wool/nylon	
FLSK-009	SKIRTING: vinyl, feather edged, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
DWWH-005	WINDOW	optional

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
FQGE-002	ARTWORK	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	

**Room Name** | Interview Room - Mental Health

**Room Number** INTF-MH

AusHFG code	Description	Group	Qty	Comment
DWWD-002	BLIND: holland	3	1	optional, roller blind in community areas, integral venetian required for hospital areas
FQBS-018	CHAIR: office, ergonomic	3	1	
FQBS-056	CHAIR: tub, mental health	3	3	
ITNE-007	COMPUTER: desktop, with display screen	3	1	
FQDW-040	DESK: fixed height, 1200W x 750D x 720H	3	1	
FIBM-016	NOTICEBOARD/WHITEBOARD: fixed, combined unit	2	1	
FQBS-054	STOOL: ottoman	3	1	
ITNE-049	TELEPHONE: handset, desktop	3	1	

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ITSE-006	BUTTON: duress, fixed	1	2	optional, depends on jurisdictional policy; mobile duress preferred
ELGP-208	GPO: double, wall mounted	1	2	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	
ITSE-038	READER: access control, general	1	1	optional
ELBO-015	SWITCH: light, single	1	1	lighting to have controlled switching to create low stimulus environment