

Room Name	Interview Room	Room Number INTF
Revision	4	
Issue Date	20.03.17	
BRIEFING		
Briefed Area	12.00 m ²	
Hours of Operation	24 Hours	
Occupancy	Up to 6 persons	
Acoustics	Sound attenuation level high, Acoustic privacy is required.	
Remarks		
Description / Special Requirements	A larger Interview Room to undertake confidential discussion and/ or counselling between staff, patients and or family members where required. The Interview Room may also be used as a multipurpose room for small staff groups or discussions. An external outlook is desirable. The Interview Room - Family may also be used for mental health patients. If used for this purpose an observation window (toughened glass with integral venetians) should be installed. Assumes staff will bring their own laptop / tablet (BYOD). Additional Design Considerations: A second egress door may be required for staff safety and security	
SERVICES		
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No
Lighting	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = Yes LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No
Nurse Call	NURSE CALL SYSTEM = No	

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	
FLCP-006	FLOOR FINISH: carpet, carpet tiles, 90/10 wool/nylon	
FLSK-009	SKIRTING: vinyl, feather edged, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
DWWH-005	WINDOW	Desirable (external outlook)

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FQGE-002	ARTWORK	3	1	optional
FQCW-016	BIN: waste, general, 20L	3	1	
FQBS-028	CHAIR: visitor, clinical areas	3	6	
FIBM-016	NOTICEBOARD/WHITEBOARD: fixed, combined unit	2	1	

Room Name | Interview Room

Room Number INTF

AusHFG code	Description	Group	Qty	Comment
FQTA-053	TABLE: round, 600 diam, low height	3	2	
FQTA-057	TABLE: round, 900 diam, work height	3	1	
ITNE-049	TELEPHONE: handset, desktop	3	1	
DWWD-013	WINDOW DRESSING: external window	3	0	If external window provided

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITSE-006	BUTTON: duress, fixed	1	1	
ELGP-208	GPO: double, wall mounted	1	3	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	
ELBO-015	SWITCH: light, single	1	1	