

## Interview Room - Mental Health

<b>Room Code</b>	INTV-MH
<b>Briefed Area</b>	14.00 m <sup>2</sup>
<b>Ceiling Height</b>	2.7 m
<b>Occupancy</b>	up to 6 persons
<b>Hours of Operation</b>	Up to 24 hours

**Description** | The Interview Room - Mental Health (may be referred to on projects as a Dialogue Room) provides the space and amenities for interviews, counselling, collaborative care planning and small support network discussions.

<b>Electrical</b>	PROTECTION: body protected	<input checked="" type="checkbox"/>	<b>HVAC</b>	AIRCONDITIONING: general	<input checked="" type="checkbox"/>
	PROTECTION: cardiac protected	<input type="checkbox"/>		AIRCONDITIONING: HEPA filtered	<input type="checkbox"/>
<b>Lighting</b>	LIGHTING: general	<input checked="" type="checkbox"/>		AIRCONDITIONING: positive pressure	<input type="checkbox"/>
	LIGHTING: colour corrected	<input type="checkbox"/>		AIRCONDITIONING: negative pressure	<input type="checkbox"/>
	LIGHTING: dimmable	<input checked="" type="checkbox"/>		VENTILATION: exhaust	<input type="checkbox"/>
	LIGHTING: indirect	<input type="checkbox"/>		VENTILATION: supply	<input type="checkbox"/>
<b>Nurse Call and Duress</b>	NURSE CALL SYSTEM: buttons / handset	<input type="checkbox"/>	<b>Medical Gas</b>	VENTILATION: natural	<input type="checkbox"/>
	NURSE CALL SYSTEM: annunciator	<input type="checkbox"/>		MEDICAL GAS: general anaesthesia	<input type="checkbox"/>
	DURESS: fixed	<input checked="" type="checkbox"/>		MEDICAL GAS: special care	<input type="checkbox"/>
	DURESS: wireless coverage	<input checked="" type="checkbox"/>		MEDICAL GAS: special care, neonatal ventilation	<input type="checkbox"/>
<b>Security</b>	ACCESS CONTROL: to door	<input checked="" type="checkbox"/>		MEDICAL GAS: birthing	<input type="checkbox"/>
	ACCESS CONTROL: to item / joinery	<input type="checkbox"/>	<b>Hydraulic</b>	WATER: drinking	<input type="checkbox"/>
	INTERCOM: service communications	<input type="checkbox"/>		WATER: specialty	<input type="checkbox"/>
	INTERCOM: security and access control	<input type="checkbox"/>		DRAINAGE: sanitary	<input type="checkbox"/>
	CCTV: camera coverage within room	<input type="checkbox"/>		DRAINAGE: specialty	<input type="checkbox"/>
	INTRUSION DETECTION: door monitoring	<input type="checkbox"/>	<b>Fire</b>	DETECTION: smoke	<input checked="" type="checkbox"/>
	INTRUSION DETECTION: spatial monitoring	<input type="checkbox"/>		DETECTION: heat	<input type="checkbox"/>
<b>ICT and Audio Visual</b>	AUDIO VISUAL: patient entertainment system	<input type="checkbox"/>	<b>Shielding</b>	SHIELDING: ionising radiation	<input type="checkbox"/>
	AUDIO VISUAL: visitor experience system	<input type="checkbox"/>		SHIELDING: magentic and radio frequency	<input type="checkbox"/>
	AUDIO VISUAL: virtual collaboration system	<input type="checkbox"/>	<b>Acoustics</b>	SPEECH PRIVACY:	
	AUDIO VISUAL: clinical support system	<input type="checkbox"/>		not private ..... moderate ..... private ..... confidential	
	AUDIO VISUAL: digital operating room system	<input type="checkbox"/>		NOISE SENSITIVITY:	
<b>Accessibility</b>	AUDIO: hearing augmentation	<input type="checkbox"/>		not sensitive ..... medium sensitive ..... sensitive	
	VISUAL: luminance contrast	<input checked="" type="checkbox"/>		NOISE GENERATION:	
	SIGNAGE: accessible, statutory	<input type="checkbox"/>		low ..... moderate ..... high ..... very high	

### Additional Considerations

- Requirements for the selection of suitable finishes, hardware, fixtures and fittings of a type manufactured and marketed as anti-ligature (including any weight limits for load release for certain fixtures) must be confirmed at project level based on service requirements, patient safety policies, local design guidance, risk assessments and confirmation of operational models. This includes the door, door hardware, joinery surfaces, joinery hardware, engineering services outlets and any ceiling mounted fixtures and services. All tamper proof and anti-ligature items must be installed in accordance with their manufacturer's instructions. Anti-ligature fittings may require a performance solution to be provided for the room to meet accessibility requirements. This must be considered and addressed at project level to meet applicable legislation and standards (to be confirmed with the project accessibility and building code consultants).
- All glazing (including external windows) is to be Grade A safety glass to comply with AS/NZS 2208 and AS 1288. Toughened and laminated glass with a structural interlayer is recommended. Additional requirements for glazing are to be confirmed at project level to suit the specific mental health environment (i.e. non-acute, acute, intensive care).

- It is recommended that the door set is selected as a full assembly to ensure the leaf, frame and hardware are coordinated and meet all tamper proof, anti-ligature and anti-barricade requirements when used together. Inclusion and size of a vision panel to be confirmed to suit service requirements. Privacy film may be applied to the vision panel as required.
- A second door is required for safety and security. The location of the second door will be dependent on the overall floor plan and availability of an appropriate area to egress.
- Based on a risk assessment, ceiling height is to be confirmed at a project level in combination with considerations for FF&E selection to ensure consumers cannot reach or cause damage to the ceiling or services located on the ceiling.
- Provision of a workstation is dependent on service requirements (e.g. for computer based assessments to be undertaken). Impact on furniture arrangement when workstation is included must be considered to support a positive dynamic between staff and consumers, and encourage participation of consumers as equal partners in care.
- Consider the location of wi-fi access points to ensure strong coverage is provided for mobile duress functions.
- Unique considerations for Intensive Care and Child and Adolescent areas are to be confirmed at project level to suit jurisdictional policies
- The selection of finishes in rooms for mental health units is to be carefully considered to support the provision of a welcoming, warm and therapeutic atmosphere and should aim to eliminate an institutional feel.
- Nearby access to a beverage bay or water fountain is recommended.
- Natural light and external outlook is desirable. Consider placement of windows and room orientation to suit privacy requirements.



## Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-013.08	DOOR: hinged, 1 leaf, 900 clear opening, solid, anti-ligature, standard vision panel	requirements for glazing in vision panel to be confirmed to suit the mental health environment
AFDFI-026	DOOR GLAZING FINISH: vision panel, privacy film	optional; as required to suit privacy requirements
AFDPR-001.01	DOOR PROTECTION: kickplate, to 300H	to room side
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	to corridor side as required
AFDPR-056.01	DOOR FRAME PROTECTION: full wrap, to 900H	optional; provision dependent on frame material and finish
ITSE-261	READER: security, access control, proximity card, wall mounted	optional; provision to suit security and egress requirements
DOHI-003.03	DOOR: hinged, 1 leaf, 900 clear opening, solid, anti-ligature	secondary egress
AFDPR-001.01	DOOR PROTECTION: kickplate, to 300H	to room side
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	to corridor side as required
AFDPR-056.01	DOOR FRAME PROTECTION: full wrap, to 900H	optional; provision dependent on frame material and finish
ITSE-261	READER: security, access control, proximity card, wall mounted	optional; provision to suit security and egress requirements
WIFX-156.01	WINDOW: fixed, external, double glazed, sill at 750H	optional; natural light and external outlook is desirable; consider placement and room orientation for patient privacy; requirements for glazing to be confirmed to suit the mental health environment
AHWCV-001	WINDOW COVERING: blind, roller, single	



## Finishes

CODE	DESCRIPTION	COMMENT
FLCP-006	FLOOR FINISH: carpet tiles	
FLSK-026	SKIRTING: vinyl, feather edge	
WLFI-002	WALL FINISH: paint, clinical areas	
CLTI-022.02	CEILING: drop-in tiles, acoustic, prefinished, 600 x 1200	if tamper proof and anti-ligature finish required, flush set ceiling to be provided

CODE	DESCRIPTION	COMMENT
CLCN-011	CORNICE: shadow angle, prefinished	to be square set if flush set ceiling is provided



## Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIBM-020	WHITEBOARD: fixed, magnetic, tamper proof, anti-ligature	②	1	
FIBM-057	NOTICEBOARD: fixed, fabric covered, tamper proof, anti-ligature	②	1	
FQBS-111	CHAIR: visitor, mental health	③	2	
FQBS-352	LOUNGE: 2 seat	③	1	
FQBS-354	LOUNGE: ottoman	③	2	
FQDW-104.02	WORKSTATION: straight, fixed height, 720H, 750D x 1200W	③	1	optional, dependent on operational service requirements
FQGE-002	ARTWORK: wall mounted	③	1	
ITNE-071	TELEPHONE: handset, desktop	③	1	optional, dependent on operational service requirements
ITNE-101	COMPUTER: single display screen, central processing unit (CPU), keyboard and mouse, desktop	③	1	optional, dependent on operational service requirements



## Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-201	GPO: double, wall mounted	①	2	
ELSW-001	SWITCH: light	①	1	
ITIN-036	OUTLET: data, triple RJ45, wall mounted	①	1	
ITSE-061	BUTTON: security, duress, fixed, wall mounted	①	1	