

Room Name	Interview Room	Room Number INTV
Revision	5	
Issue Date	18.01.2021	
BRIEFING		
Briefed Area	12.00 m ²	
Hours of Operation	24 Hours	
Occupancy	Up to 8 persons	
Acoustics	Sound attenuation level high, Acoustic privacy is required.	
Remarks		
Description / Special Requirements	The Interview Room provides space for confidential discussion and/or counselling between staff, patients and/or family members where required. The Interview Room may also be used as a multipurpose room for small staff groups or discussions. An external outlook is desirable. Assumes staff will bring their own devices as required. A second door may be required for staff safety and security; the location of the second door will be dependent on the availability an appropriate area to egress. An operational model for responding to calls from staff/patients will be needed to support the inclusion of a nurse call system and is to be determined based on service requirements	
SERVICES		
General Requirements	BODY PROTECTED <input type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
Air	AIRCONDITIONING <input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure <input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust <input type="checkbox"/>	VENTILATION <input type="checkbox"/>
Lighting	LIGHTING: colour corrected <input type="checkbox"/>	LIGHTING: dimmable <input checked="" type="checkbox"/>
	LIGHTING: downlights <input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights <input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general <input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
Nurse Call	NURSE CALL SYSTEM <input checked="" type="checkbox"/>	

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-009	CORNICE: wall trim fixing	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	second door is optional for egress
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional
FLCP-006	FLOOR FINISH: carpet, carpet tiles, 90/10 wool/nylon	
FLSK-009	SKIRTING: vinyl, feather edged, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
DWWH-005	WINDOW	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FQGE-002	ARTWORK	3	1	optional
DWWD-004	BLIND: roller	3	1	

Room Name | Interview Room
Room Number INTV

AusHFG code	Description	Group	Qty	Comment
FQBS-010	CHAIR: armchair	3	1	
FQBS-058	CHAIR: visitor, patient, with arms	3	4	
FQBS-041	LOUNGE: 2.5 seat	3	1	
FQTA-075	TABLE: square, 600W, low height	3	2	
ITNE-050	TELEPHONE: handset, desktop, handsfree	3	1	
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITSE-006	BUTTON: duress, fixed	1	1	
ITCL-004	BUTTON: nurse call, emergency	1	1	optional, + indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	optional, + indicator button & light
ELGP-208	GPO: double, wall mounted	1	2	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	
ITSE-038	READER: access control, general	1	1	optional to second egress door
ELBO-015	SWITCH: light, single	1	1	