

Room Name | Lounge - Parent, 12m2
Room Number LNPA-12
Revision 5
Issue Date 20.03.17

BRIEFING
Briefed Area 12.00 m²
Hours of Operation 24 Hours
Occupancy Up to 6 visitors
Acoustics Sound attenuation level medium, Acoustic privacy is required.
Remarks
Description / Special Requirements The Parent Lounge provides a change of environment away from clinical areas for parents or visitors to patients in the Paediatric/ Adolescent Unit, NNIC and SCN. An external outlook is desirable. Door width should allow access for twin prams. Indirect lighting is optional.

SERVICES

General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No
Lighting	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = Yes
Nurse Call	NURSE CALL SYSTEM = No	

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
DWGL-031	DOOR: 1400mm c/o, 1 1/2 leaf, half glazed, solid core/glass, paint	910 /1400mm clear opening, small door leaf optional
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	Equal to Acrovyn
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	Equal to Acrovyn
FLCP-003	FLOOR FINISH: carpet, broadloom, 48 oz., 90/10 wool/nylon	Default = carpet; vinyl also acceptable
DWOB-002	OBSERVATION: internal window, alum/glass, door height, powdercoat	optional
FLSK-009	SKIRTING: vinyl, feather edged, 150H, prefinished	or vinyl coved skirting
WLWA-004	WALL FINISH: paint, acrylic, washable	
DWWH-005	WINDOW	desirable

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FQGE-002	ARTWORK	3	1	optional
DWWD-006	BLIND: venetian	3	1	to internal windows, optional
FIHR-006	BRACKET: for display screen, wall mounted	1	1	optional
FQBS-028	CHAIR: visitor, clinical areas	3	2	

Room Name | Lounge - Parent, 12m2

Room Number LNPA-12

AusHFG code	Description	Group	Qty	Comment
DWWD-011	CURTAIN: window, drapes	3	2	or blinds
ITBU-011	DISPLAY SCREEN: MATV	3	1	54cm screen
FQBS-039	LOUNGE: 1 seat	3	4	
FQTA-075	TABLE: square, 600W, low height	3	3	
ITNE-049	TELEPHONE: handset, desktop	3	1	on table, optional
FIRT-030	TRACK: curtain, flat pelmet	1	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELGP-106	GPO: single, special, for equipment	1	1	TV, optional
ELGP-109	GPO: single, wall mounted	1	4	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	1 outlet for telephone
ITIN-070	OUTLET: MATV	1	1	optional
ELBO-015	SWITCH: light, single	1	1	