

Room Name	Mammography		Room Number MAMMO
Revision	3		
Issue Date	20.03.17		
BRIEFING			
Briefed Area	16.00 m ²		
Hours of Operation	Available 24 Hours		
Occupancy	1 patient; Up to 2 staff assisting		
Acoustics	Acoustic privacy is required		
Remarks			
Description / Special Requirements	X-ray room for mammography imaging procedures, with change area within the room. Additional Design Considerations: Radiation shielding as advised by Radiation Consultant. Cable ducts between X-ray table and control area may be required. 'X-ray in Use' lights required outside each entry door.		
SERVICES			
General Requirements	BODY PROTECTED = Yes	CARDIAC PROTECTED = No	
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No	
Lighting	LIGHTING: colour corrected = Yes LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = No	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = Yes LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No	
Nurse Call	NURSE CALL SYSTEM = Yes		

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWSC-026	DOOR: 1600mm c/o, 1 1/2 leaf, solid core, lead shielding, paint	min. 1400mm clear opening
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	equal to Acrovyn
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	equal to Acrovyn
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLVY-009	FLOOR FINISH: vinyl, seamless, coved, wet area, non-slip	to basin
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	to basin

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	refer to BHWS-B (similar)
FQCW-016	BIN: waste, general, 20L	3	1	to basin
FQBS-014	CHAIR: client	3	1	to change area
MMGE-018	CHAIR: mammography	3	1	'Hausted'

Room Name | Mammography
Room Number MAMMO

AusHFG code	Description	Group	Qty	Comment
FQBS-018	CHAIR: office, ergonomic	3	1	to desk
FIJO-116	CUPBOARD: tall, double door, adj shelves	1	1	
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	1	above desk, optional
FQGE-010	CURTAIN: privacy screen	3	1	to change area
FQDW-001	DESK: adj height, 1100W x 600D x 750H nom.	3	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
FIHR-026	HOOK: coat	1	2	to change area, 1 @1200H
FIBM-006	MIRROR: fixed, glass	1	1	to change area
MMMI-156	SYSTEM: imaging, mammography	1	1	with control panel
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
ITNE-049	TELEPHONE: handset, desktop	3	1	to desk
FIRT-032	TRACK: curtain, privacy, L shaped	1	1	to change area
MMGE-152	VIEWER: X-ray, 2 screen	1	1	above desk

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	
ITCL-009	BUTTON: nurse call, staff / nurse assist	1	1	
ITCL-008	BUTTON: nurse call, staff assist	1	1	
ELGE-001	DIRECT CONNECTION: power	1	1	
ELGP-208	GPO: double, wall mounted	1	3	2 to desk area
ELGP-209	GPO: double, wall mounted, RCD protected	1	1	
ELGP-123	GPO: emergency power, single, wall mounted	1	2	
ELGP-106	GPO: single, special, for equipment	1	1	Mammography unit
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
LIFX-008	LIGHT: task light, built in	1	1	to desk area
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	to desk, 1 outlet for telephone
WLSH-004	SHIELDING: lead lining	1	1	to walls and doors as specified
ELBO-015	SWITCH: light, single	1	3	