

Room Name	Mammography Room		Room Number MAMMO
Revision	4		
Issue Date	29.05.2019		
BRIEFING			
Briefed Area	16.00 m ²		
Hours of Operation	Available 24 Hours		
Occupancy	1 patient; Up to 2 staff assisting		
Acoustics	Acoustic privacy is required		
Remarks			
Description / Special Requirements	X-ray room for mammography imaging. Additional Design Considerations: Radiation shielding as advised by Radiation Consultant. Cable ducts between mammography unit and control area will be required. 'X-ray in Use' lights required outside each entry door.		
SERVICES			
General Requirements	BODY PROTECTED	<input checked="" type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
Air	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION <input type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input checked="" type="checkbox"/>	LIGHTING: dimmable <input checked="" type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
Nurse Call	NURSE CALL SYSTEM	<input checked="" type="checkbox"/>	

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	tiled ceiling also acceptable if interventional procedures are not undertaken
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWSC-005	DOOR: 910mm c/o, single leaf, solid core, lead shielding, paint	
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	floor finish must be minimum slip rating R10; Pendulum P3 or agreed equivalent to extend under basin
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	to basin
WLWA-025	WALL FINISH: vinyl, to 1200 AFFL	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	1	

Room Name | Mammography Room
Room Number MAMMO

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	
FQCW-016	BIN: waste, general, 20L	3	1	to basin
FIHR-075	BRACKET: for computer CPU, underdesk mounted	2	1	
FIHR-005	BRACKET: for display screen, PACS, wall mounted	3	1	
FIHR-019	BRACKET: for suction bottle	2	1	
FIJO-099	CAC: cable access cap	3	1	
FQBS-018	CHAIR: office, ergonomic	3	1	to desk
MMGE-019	CHAIR: patient	3	1	
ITCL-014	CLOCK: analogue, electric	1	1	
ITNE-068	COMPUTER: hi performance, for clinical / PACS use, CPU, underbench mount	3	1	
MMMI-162	CONSOLE: control, mammography	1	1	
FQGE-010	CURTAIN: privacy screen	3	1	to entry door
MMMI-159	DEVICE: imaging, mammography	1	1	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
ITNE-070	DISPLAY SCREEN: PACS	3	2	
MGFP-004	FLOWMETER: oxygen	3	1	
FIHR-026	HOOK: coat	1	2	optional, for patient changing, 1 @1200H
ITNE-067	KEYBOARD: keyboard and mouse only	3	1	
MMGE-048	LINEN CARRIER: dirty, single	3	1	
FQSM-003	PEDESTAL: mobile, wire basket unit, 840H	3	1	
FIHR-055	RACK: scanhead	3	1	
MMGE-100	SUCTION BOTTLE	3	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	
ITNE-049	TELEPHONE: handset, desktop	3	1	to desk
FIRT-040	TRACK: curtain, privacy, L shaped, angled	1	1	
FQDW-028	WORKSTATION: straight, adj height, 1200W x 750D x 750H nom.	3	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITSE-006	BUTTON: duress, fixed	1	1	
ITCL-004	BUTTON: nurse call, emergency	1	1	
ITCL-008	BUTTON: nurse call, staff assist	1	1	on service panel
ELGP-223	GPO: emergency power, double, wall mounted	1	2	
ELGP-122	GPO: emergency power, single, on services panel	1	2	

Room Name | Mammography Room
Room Number MAMMO

AusHFG code	Description	Group	Qty	Comment
ELGP-123	GPO: emergency power, single, wall mounted	1	3	imaging and control equipment
ELGP-105	GPO: single, on services panel	1	2	
ELGP-109	GPO: single, wall mounted	1	1	x-ray viewer
ELGP-109	GPO: single, wall mounted	1	1	clock
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
LIFX-002	LIGHT: illuminated sign, "X-Ray in Use"	1	1	auto on when modality is in use
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	to desk, 1 outlet for telephone
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	3	
MGAS-042	OUTLET: oxygen (O2), on services panel	1	1	
MGAS-062	OUTLET: suction, on services panel	1	1	
ELPR-006	RCD: residual current device	1	2	to services panel
MMSP-026	SERVICES PANEL: wall mounted	1	1	
WLSH-004	SHIELDING: lead lining	1	1	
ELBO-012	SWITCH: light, dimmer	1	1	