

Room Name Meeting Room, 12m2

Room Number MEET-12

Revision

5

Issue Date

20.03.17

BRIEFING
Briefed Area

 12.00 m²
Hours of Operation

8am to 10 pm daily

Occupancy

Up to 8

Acoustics

Sound attenuation level high, Acoustic privacy is required.

Remarks
**Description /
Special Requirements**

A multipurpose room for interviews, meetings, teaching and training activities. An external outlook is desirable. The room may be located in close proximity to a Beverage Bay as required. Size of space and FF&E quantity/type to be adapted to suit specific project briefing requirements as per AusHFG HPU's. Add 1.2m2 per additional person and allow 1.5m2 for wheelchair parking space as required.

SERVICES
General Requirements

BODY PROTECTED = No

CARDIAC PROTECTED = No

Air

AIRCONDITIONING = Yes

AIRCONDITIONING: hepa filtered = No

AIRCONDITIONING: positive pressure = No

AIRCONDITIONING: negative pressure = No

EXHAUST: room exhaust = No

VENTILATION = No

Lighting

LIGHTING: colour corrected = No

LIGHTING: dimmable = No

LIGHTING: downlights = No

LIGHTING: downlights, dimmable = Yes

LIGHTING: fluorescent, downlights = No

LIGHTING: fluorescent, flush with ceiling, tamper proof = No

LIGHTING: fluorescent, general = Yes

LIGHTING: indirect = No

Nurse Call

NURSE CALL SYSTEM = No

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	optional, egress door
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	910/1400mm clear opening, lockable; small leaf optional
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	Optional. To be decided at project level.
FLCP-006	FLOOR FINISH: carpet, carpet tiles, 90/10 wool/nylon	Slip resistant vinyl also acceptable.
FLSK-009	SKIRTING: vinyl, feather edged, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
DWWH-005	WINDOW	desirable

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FQCW-016	BIN: waste, general, 20L	3	1	
DWWD-006	BLIND: venetian	3	0	Internal window, if provided.
FQBS-017	CHAIR: meeting room	3	8	May be stackable. Consider weight capacity.

Room Name | Meeting Room, 12m2

Room Number MEET-12

AusHFG code	Description	Group	Qty	Comment
FQGE-005	CLOCK: analogue, battery operated	3	1	
FQTA-020	TABLE: rectangular, 1500L x 1200W, work height	3	1	
ITNE-050	TELEPHONE: handset, desktop, handsfree	3	1	
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	
DWWD-014	WINDOW DRESSING: external window, blackout	3	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELGP-208	GPO: double, wall mounted	1	4	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	Wall phone.
ITIN-070	OUTLET: MATV	1	1	Optional. May be replaced with data outlet, in accordance with ICT policy
ELBO-015	SWITCH: light, single	1	1	