

**Room Name** Meeting Room, 12m2

**Room Number** MEET-12

**Revision**

5

**Issue Date**

20.03.17

**BRIEFING**
**Briefed Area**

12.00 m<sup>2</sup>
**Hours of Operation**

8am to 10 pm daily

**Occupancy**

Up to 8

**Acoustics**

Sound attenuation level high, Acoustic privacy is required.

**Remarks**
**Description /  
Special Requirements**

A multipurpose room for interviews, meetings, teaching and training activities. An external outlook is desirable. The room may be located in close proximity to a Beverage Bay as required. Size of space and FF&E quantity/type to be adapted to suit specific project briefing requirements as per AustHFG HPUs. Add 1.2m2 per additional person and allow 1.5m2 for wheelchair parking space as required.

**SERVICES**
**General Requirements**

BODY PROTECTED = No

CARDIAC PROTECTED = No

**Air**

AIRCONDITIONING = Yes

AIRCONDITIONING: hepa filtered = No

AIRCONDITIONING: positive pressure = No

AIRCONDITIONING: negative pressure = No

EXHAUST: room exhaust = No

VENTILATION = No

**Lighting**

LIGHTING: colour corrected = No

LIGHTING: dimmable = No

LIGHTING: downlights = No

LIGHTING: downlights, dimmable = Yes

LIGHTING: fluorescent, downlights = No

LIGHTING: fluorescent, flush with ceiling, tamper proof = No

LIGHTING: fluorescent, general = Yes

LIGHTING: indirect = No

**Nurse Call**

NURSE CALL SYSTEM = No

# RETIRED

**Room Fabrics**

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	optional, egress door
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	910/1400mm clear opening, lockable; small leaf optional
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	Optional. To be decided at project level.
FLCP-006	FLOOR FINISH: carpet, carpet tiles, 90/10 wool/nylon	Slip resistant vinyl also acceptable.
FLSK-009	SKIRTING: vinyl, feather edged, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
DWWH-005	WINDOW	desirable

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
FQCW-016	BIN: waste, general, 20L	3	1	
DWWD-006	BLIND: venetian	3	0	Internal window, if provided.
FQBS-017	CHAIR: meeting room	3	8	May be stackable. Consider weight capacity.

**Room Name** | Meeting Room, 12m2

**Room Number** MEET-12

AusHFG code	Description	Group	Qty	Comment
FQGE-005	CLOCK: analogue, battery operated	3	1	
FQTA-020	TABLE: rectangular, 1500L x 1200W, work height	3	1	
ITNE-050	TELEPHONE: handset, desktop, handsfree	3	1	
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	
DWWD-014	WINDOW DRESSING: external window, blackout	3	1	

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ELGP-208	GPO: double, wall mounted	1	4	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	Wall phone.
ITIN-070	OUTLET: MATV	1	1	Optional. May be replaced with data outlet, in accordance with ICT policy
ELBO-015	SWITCH: light, single	1	1	

# RETIRED