

Room Name	Meeting Room, 9m2		Room Number	MEET-9
Revision	5			
Issue Date	20.03.17			
BRIEFING				
Briefed Area	9.00 m ²			
Hours of Operation	24 Hours			
Occupancy	Up to 4			
Acoustics	Sound attenuation level high, Acoustic privacy is required.			
Remarks				
Description / Special Requirements	A multipurpose room for staff interviews, meetings, teaching and training activities. May also function as a 'breakout' room in an open workstation environment. An external outlook is desirable. Size of space and FF&E quantity/type to be adapted to suit specific project briefing requirements as per AusHFG HPU's. Add 1.2m2 per additional person and allow 1.5m2 for wheelchair parking space as required.			
SERVICES				
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No		
Air	AIRCONDITIONING = Yes	AIRCONDITIONING: hepa filtered = No		
	AIRCONDITIONING: positive pressure = No	AIRCONDITIONING: negative pressure = No		
	EXHAUST: room exhaust = No	VENTILATION = No		
Lighting	LIGHTING: colour corrected = No	LIGHTING: dimmable = No		
	LIGHTING: downlights = No	LIGHTING: downlights, dimmable = No		
	LIGHTING: fluorescent, downlights = No	LIGHTING: fluorescent, flush with ceiling, tamper proof = No		
	LIGHTING: fluorescent, general = Yes	LIGHTING: indirect = No		
Nurse Call	NURSE CALL SYSTEM = No			

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-002	DOOR: 910mm c/o, single leaf, half glazed, solid core/glass, paint	910mm clear opening, lockable, glazing optional
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	Optional. To be decided at project level.
FLCP-006	FLOOR FINISH: carpet, carpet tiles, 90/10 wool/nylon	Slip resistant vinyl also acceptable.
DWOB-004	OBSERVATION: internal window, alum/glass, internal blinds, powdercoat	Optional
FLSK-009	SKIRTING: vinyl, feather edged, 150H, prefinished	default = feather edged : or floor vinyl coved skirting
WLWA-004	WALL FINISH: paint, acrylic, washable	
DWWH-005	WINDOW	Desirable

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FQCW-016	BIN: waste, general, 20L	3	1	

Room Name | Meeting Room, 9m2

Room Number MEET-9

AusHFG code	Description	Group	Qty	Comment
DWWD-003	BLIND: integral	1	1	To optional internal window, if provided.
FQBS-028	CHAIR: visitor, clinical areas	3	4	Consider weight capacity
FIHR-026	HOOK: coat	1	2	Optional
FQTA-017	TABLE: rectangular 1200L x 900W, work height	3	1	
ITNE-049	TELEPHONE: handset, desktop	3	1	On table
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	
DWWD-013	WINDOW DRESSING: external window	3	1	Number to align with window configuration, if provided. Window dressing type to comply with Infection Control policy. Blackout may be required if used for audiovisual presentations.

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELGP-208	GPO: double, wall mounted	1	2	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	Wall phone.
ELBO-015	SWITCH: light, single	1	1	