

Room Name	Mortuary - Autopsy Room		Room Number MOR-AU
Revision	3		
Issue Date	20.03.17		
BRIEFING			
Briefed Area	30.00 m ²		
Hours of Operation	Available 24 Hours		
Occupancy	Up to 4		
Acoustics			
Remarks			
Description / Special Requirements	Room for undertaking post mortem examinations. The Autopsy Room should be located adjacent to the Body Cool Store and have ready access to a clean-up area. Additional Design Considerations: Doors to be sealed for odours. Post mortem table to have water flushing system. An observation area is optional.		
SERVICES			
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No	
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = Yes	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No	
Lighting	LIGHTING: colour corrected = Yes LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = No	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No	
Nurse Call	NURSE CALL SYSTEM = No		

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-033	DOOR: 1400mm c/o, 1 1/2 leaf, observation panel, solid core/glass, paint	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	equal to Acrovyn
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	equal to Acrovyn
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
DWOB-002	OBSERVATION: internal window, alum/glass, door height, powdercoat	observation window/s
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-020	WALL FINISH: vinyl, to 1500 AFFL	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	1	to table
HYBA-009	BASIN: handwash, Type A, scrub	1	1	Refer BHWS-A (similar)
FIJO-021	BENCH: 600D, open under, stainless steel lipped	1	1	with wet edge & draining sink

Room Name | Mortuary - Autopsy Room
Room Number MOR-AU

AusHFG code	Description	Group	Qty	Comment
FQCW-006	BIN: waste, clinical, 240L	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	
FQCW-044	BIN: waste, sharps, wall mounted	3	1	
FIHR-016	BRACKET: for sharps bin	2	1	
MMOP-003	CABINET: instrument	3	1	
FQGE-005	CLOCK: analogue, battery operated	3	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
HYTP-003	HOSE REEL: retractable	1	1	
LIFX-013	LIGHT: procedure, ceiling mounted, small	1	1	
MMOP-065	SAW: surgical	3	1	
FIJO-197	SHELF: stainless steel, underbench	1	3	under SS bench
HYBA-044	SINK: draining	1	1	in bench, sensor taps, hot water
HYBA-055	SINK: single, 500 x 450 x 250D	1	1	sensor taps, hot water
MMOP-071	STOOL: operating, mobile	3	1	
MMLA-080	TABLE: post mortem	1	1	& medical gases to pedestal
HYTP-042	TAPWARE: sensor	1	1	to basin
HYTP-042	TAPWARE: sensor	1	2	to sinks
ITNE-053	TELEPHONE: handset, wall mount, handsfree	3	1	
FQSM-016	TROLLEY	3	1	
MMGE-152	VIEWER: X-ray, 2 screen	1	1	recessed
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	900x900, optional

Engineering Services

AusHFG code	Description	Group	Qty	Comment
HYDR-004	DRAIN: floor waste	1	2	1 under sink, with removable filtered trap
HYDR-001	DRAIN: special requirements	1	2	confirm special requirements at project level
ELGP-208	GPO: double, wall mounted	1	1	
ELGP-122	GPO: emergency power, single, on services panel	1	1	to services panel on table
ELGP-123	GPO: emergency power, single, wall mounted	1	1	to bench
ELGP-105	GPO: single, on services panel	1	2	to services panel on table
ELGP-109	GPO: single, wall mounted	1	2	to bench
ITSE-029	INTERCOM: audio, wall mount	1	1	
MGAS-062	OUTLET: suction, on services panel	1	1	to services panel on table
MGAS-073	OUTLET: tool air, on services panel	1	1	to services panel on table

Room Name | Mortuary - Autopsy Room

Room Number MOR-AU

AusHFG code	Description	Group	Qty	Comment
MMSP-025	SERVICES PANEL: special	2	1	on table
ELBO-015	SWITCH: light, single	1	1	
ITNE-054	TELEPHONE PABX	1	1	wall phone, handsfree