

Room Name	Mortuary - Autopsy Room		Room Number MOR-AU
Revision	4		
Issue Date	18.01.2021		
BRIEFING			
Briefed Area	30.00 m ²		
Hours of Operation	Available 24 Hours		
Occupancy	Up to 4		
Acoustics			
Remarks			
Description / Special Requirements	The Mortuary - Autopsy Room is for undertaking post mortem examinations. An observation area is to be provided to at least one Autopsy Room within a department. Layout of tables and orientation of observation bay may be adjusted to suit the type of autopsy being performed (e.g. coronial or non-coronial). The Mortuary - Autopsy Room should be located with ready access to Mortuary - Body Holding. Additional Design Considerations: doors to be sealed for odours, post mortem table to have water flushing system. Appropriate Smoke/Heat detection to be considered.		
SERVICES			
General Requirements	BODY PROTECTED	<input type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
Air	AIRCONDITIONING	<input type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure <input checked="" type="checkbox"/>
	EXHAUST: room exhaust	<input checked="" type="checkbox"/>	VENTILATION <input type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input checked="" type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
Nurse Call	NURSE CALL SYSTEM	<input type="checkbox"/>	

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWGL-033	DOOR: 1400mm c/o, 1 1/2 leaf, observation panel, solid core/glass, paint	door seals required
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	door seals required
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional
FLVY-004	FLOOR FINISH: vinyl, seamless, coved, non-slip, safety	junction with evisceration table to be considered to prevent water ingress
DWOB-005	OBSERVATION: internal window, alum/glass, powdercoat	to observation area if provided
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-023	WALL FINISH: vinyl, to 2100 AFFL	

Fittings, Furniture and Equipment (FF&E) Items

Room Name | Mortuary - Autopsy Room
Room Number MOR-AU

AusHFG code	Description	Group	Qty	Comment
HYBA-009	BASIN: handwash, Type A, scrub	1	1	
FIJO-021	BENCH: 600D, open under, stainless steel lipped	1	1	with wet edge and integral sink
FIJO-100	BENCH LEGS: stainless steel, for bench top	1	1	
FQCW-004	BIN: waste, clinical, 120L	3	1	
FQCW-015	BIN: waste, general, 120L	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	to basin
FQCW-043	BIN: waste, sharps, on trolley	3	1	
FQCW-044	BIN: waste, sharps, wall mounted	3	1	
FIHR-067	BRACKET: for monitor, wall mounted, articulated, adj height	2	1	
FIHR-016	BRACKET: for sharps bin	2	2	
FQGE-005	CLOCK: analogue, battery operated	3	1	
ITNE-066	COMPUTER: all-in-one, wall mounted	3	1	suitable for use in wet zone
FIDI-014	DISPENSER: disposable glove	2	1	to basin
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	2	to basin
FIRT-005	GRAB RAIL: stainless steel	1	2	to boot wash
FIRT-046	GRAB RAIL: stainless steel, freestanding	1	1	to boot wash
FIHR-029	HOOK: equipment	1	1	optional, for lifter straps/slings
HYTP-003	HOSE REEL: retractable	1	1	
ITNE-067	KEYBOARD: keyboard and mouse only	3	1	suitable for use in wet zone
MMBE-070	LIFTER: patient, ceiling mounted, motor and sling component, mortuary	3	1	optional, mobile lifter may be used, bariatric capacity to be confirmed based on service requirements; control may be suspended from motor or wall mounted depending on model
MMBE-071	LIFTER: patient, ceiling mounted, track, linear, mortuary	1	1	optional, mobile lifter may be used, bariatric capacity to be confirmed based on service requirements
LIFX-037	LIGHT: LED strip, ceiling mounted	1	1	task lighting over dissection table, articulated task light is also acceptable dependent on service requirements
LIFX-014	LIGHT: procedure, ceiling mounted	1	1	hardwired, a second light may be provided dependent on service requirements
MMGE-048	LINEN CARRIER: dirty, single	3	1	
MMGE-185	SCALES: digital, benchtop	3	1	
HYTP-023	SHOWER: safety, eyewash combination	1	1	
HYBA-055	SINK: single, 500 x 450 x 250D	1	1	
HYTP-028	SPOUT: bath, wall mounted	1	1	to boot wash
FQBS-051	STOOL: mobile, adj height	3	1	optional, dependent on project requirements

Room Name | Mortuary - Autopsy Room
Room Number MOR-AU

AusHFG code	Description	Group	Qty	Comment
MMLA-087	TABLE: dissection, height adjustable	1	1	with integral sink
MMLA-086	TABLE: evisceration, height adjustable	1	1	bariatric capacity to be determined based on service requirements, services on table to be considered: suction capabilities (built-in or provided), power to table, power outlets (if not on table), down draft (optional, built-in to table), water connection (built-in to table)
HYTP-030	TAPWARE: cold	1	1	to boot wash
HYTP-034	TAPWARE: laboratory	1	1	to dissection table
HYTP-038	TAPWARE: mixer, elbow levers, long	1	2	
ITNE-053	TELEPHONE: handset, wall mount, handsfree	3	1	suitable for use in wet zone
MMGE-119	TROLLEY: equipment	3	2	
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	optional

Engineering Services

AusHFG code	Description	Group	Qty	Comment
HYDR-003	DRAIN: floor trough	1	2	
HYDR-004	DRAIN: floor waste	1	1	to boot wash
HYDR-001	DRAIN: special requirements	1	1	to evisceration table, confirm requirements at project level
MEEEX-017	EXHAUST: downdraft, mortuary	1	1	optional, on evisceration and dissection tables, dependent on service requirements and vendor specifications
ELGP-223	GPO: emergency power, double, wall mounted	1	2	IP rated to suit AS/NZS wet zone requirements
ELGP-123	GPO: emergency power, single, wall mounted	1	1	to computer. IP rated to suit AS/NZS wet zone requirements
ELGP-106	GPO: single, special, for equipment	1	2	power to evisceration and dissection tables (if not part of table configuration). Required to be emergency power/generator backed. IP rated to suit AS/NZS wet zone requirements
ELGP-106	GPO: single, special, for equipment	1	8	4x outlets on evisceration and dissection tables, dependent on service requirements and vendor specifications. Required to be emergency power/generator backed. IP rated to suit AS/NZS wet zone requirements
ITSE-029	INTERCOM: audio, wall mount	1	1	suitable for use in wet zone
HYTP-008	OUTLET: cold water	1	2	connection only, to evisceration and dissection tables, dependent on service requirements and vendor specifications
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	IP rated to suit AS/NZS wet zone requirements

Room Name | Mortuary - Autopsy Room
Room Number MOR-AU

AusHFG code	Description	Group	Qty	Comment
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	3	IP rated to suit AS/NZS wet zone requirements
HYTP-012	OUTLET: hosecock, cold water	1	1	to hose reel
HYTP-013	OUTLET: hot water	1	2	connection only, to evisceration and dissection tables, dependent on service requirements and vendor specifications
MGAS-060	OUTLET: suction	1	2	on evisceration and dissection tables, dependent on service requirements and vendor specifications
ELBO-015	SWITCH: light, single	1	2	1x general room lights, 1x task light over dissection bench. IP rated to suit AS/NZS wet zone requirements
HYGE-026	TROUGH: boot wash	1	1	