

Room Name	Mortuary - Body Holding		Room Number MOR-BH
<b>Revision</b>	4		
<b>Issue Date</b>	18.01.2021		
<b>BRIEFING</b>			
<b>Briefed Area</b>	22.00 m <sup>2</sup>		
<b>Hours of Operation</b>	24 Hours		
<b>Occupancy</b>	1 - 2 staff intermittently		
<b>Acoustics</b>			
<b>Remarks</b>			
<b>Description / Special Requirements</b>	The Mortuary - Body Holding provides refrigerated storage for the temporary holding of bodies with an adjacent area to transfer a body from a trolley into storage. The room can be configured with refrigerated cabinets or as a cool room depending on service requirements. The Mortuary - Body Holding should be located with ready access to the Mortuary - Viewing Room.		
<b>SERVICES</b>			
<b>General Requirements</b>	BODY PROTECTED	<input type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
<b>Air</b>	AIRCONDITIONING	<input type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure <input checked="" type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION <input type="checkbox"/>
<b>Lighting</b>	LIGHTING: colour corrected	<input type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
<b>Nurse Call</b>	NURSE CALL SYSTEM	<input type="checkbox"/>	

**Room Fabrics**

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWGL-033	DOOR: 1400mm c/o, 1 1/2 leaf, observation panel, solid core/glass, paint	
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional
FLVY-004	FLOOR FINISH: vinyl, seamless, coved, non-slip, safety	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-025	WALL FINISH: vinyl, to 1200 AFFL	
WLPR-006	WALL PROTECTION: corner guards	
WLPR-021	WALL PROTECTION: crash rail, at 900 AFFL	

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	
FQCW-016	BIN: waste, general, 20L	3	1	to basin

**Room Name | Mortuary - Body Holding**
**Room Number MOR-BH**

AusHFG code	Description	Group	Qty	Comment
FIDI-014	DISPENSER: disposable glove	2	1	to basin
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
MMGE-183	FRIDGE: body holding, triple tier	1	3	bariatric capacity to be confirmed based on service requirements; power and BMS requirements to be confirmed by project
FIHR-029	HOOK: equipment	1	1	for lifter straps/slings
HYTP-003	HOSE REEL: retractable	1	1	
MMBE-070	LIFTER: patient, ceiling mounted, motor and sling component, mortuary	3	1	mobile lifter may be used, bariatric capacity to be confirmed based on service requirements; control may be suspended from motor or wall mounted depending on model
MMBE-071	LIFTER: patient, ceiling mounted, track, linear, mortuary	1	1	mobile lifter may be used, bariatric capacity to be confirmed based on service requirements
HYTP-037	TAPWARE: mixer, elbow levers	1	1	
MMGE-133	TROLLEY: mortuary, hydraulic	3	1	bariatric capacity to be confirmed based on service requirements

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ITBU-001	ALARM: equipment monitoring, temperature	1	1	temperature monitoring, alarm and BMS requirements to be confirmed by project
HYDR-004	DRAIN: floor waste	1	1	
ELGP-101	GPO: single, ceiling mounted	1	1	to lifter
ELGP-106	GPO: single, special, for equipment	1	3	1 to each refrigerator; required to be emergency power/generator backed. IP rated to suit AS/NZS wet zone requirements
ELGP-110	GPO: single, wall mounted, cleaner	1	1	IP rated to suit AS/NZS wet zone requirements
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	3	temperature monitoring, IP rated to suit AS/NZS wet zone requirements, 1 to each refrigerator, BMS requirements to be confirmed by project
HYTP-012	OUTLET: hosecock, cold water	1	1	
ELBO-015	SWITCH: light, single	1	1	IP rated to suit AS/NZS wet zone requirements