

Room Name | Mortuary - Clean-up Area

Room Number MOR-CU

Revision 3
Issue Date 20.03.17

BRIEFING

Briefed Area 6.00 m²
Hours of Operation 24 Hours
Occupancy 1 - 2 intermittently
Acoustics
Remarks
Description / Special Requirements The Mortuary Clean-up is a small Utility Room providing for cleaning and holding of used equipment for collection, disposal of clinical and other wastes and soiled linen used in the Mortuary area.

SERVICES
General Requirements

BODY PROTECTED = No CARDIAC PROTECTED = No

Air

 AIRCONDITIONING = No AIRCONDITIONING: hepa filtered = No
 AIRCONDITIONING: positive pressure = No AIRCONDITIONING: negative pressure = No
 EXHAUST: room exhaust = Yes VENTILATION = Yes

Lighting

 LIGHTING: colour corrected = No LIGHTING: dimmable = No
 LIGHTING: downlights = No LIGHTING: downlights, dimmable = No
 LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No
 LIGHTING: fluorescent, general = Yes LIGHTING: indirect = No

Nurse Call

NURSE CALL SYSTEM = No

RETIRED

Room Fabrics

AusHFG code	Description	Comment
CLTI-014	CEILING: plasterboard, water resistant, drop-in tiles, prefinished, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	pull handle/push plate, closer
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	equal to Acrovyn
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	equal to Acrovyn
FLVY-004	FLOOR FINISH: vinyl, seamless, coved, non-slip, safety	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-020	WALL FINISH: vinyl, to 1500 AFFL	tiles also acceptable

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	refer to BHWS-B (similar)
FIJO-021	BENCH: 600D, open under, stainless steel lipped	1	1	with wet edge
FQCW-006	BIN: waste, clinical, 240L	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	
FQCW-044	BIN: waste, sharps, wall mounted	3	1	

Room Name | Mortuary - Clean-up Area

Room Number MOR-CU

AusHFG code	Description	Group	Qty	Comment
FIHR-016	BRACKET: for sharps bin	2	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to handbasin
FIDI-030	DISPENSER: soap	2	1	to handbasin
FIDI-031	DISPENSER: soap antiseptic	2	1	to handbasin
HYTP-006	HOSE: spray, pressure control	1	1	to flushing rim sink, with flush button
FIJO-196	SHELF: stainless steel, overbench, wall mount	1	1	over bench
FIJO-197	SHELF: stainless steel, underbench	1	1	under bench
HYBA-046	SINK: flushing rim	1	1	with hose spray
HYBA-052	SINK: single, 450 x 350 x 250D	1	1	hot water
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to sink
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	600x900, optional

Engineering Services

AusHFG code	Description	Group	Qty	Comment
HYDR-004	DRAIN: floor			
ELGP-109	GPO: single, wall mounted	1	1	
ELBO-015	SWITCH: light, single	1	2	

RETIRED