

| Room Name | Mortuary - Waiting | | Room Number MOR-W |
|---|---|--|-------------------|
| Revision | 4 | | |
| Issue Date | 20.03.17 | | |
| BRIEFING | | | |
| Briefed Area | 9.00 m ² | | |
| Hours of Operation | 24 Hours | | |
| Occupancy | Up to 4 | | |
| Acoustics | | | |
| Remarks | | | |
| Description / Special Requirements | The Mortuary Waiting provides an area for relatives and other personnel to await the viewing of a body. The area should be comfortable and non-clinical in appearance. The Viewing Room will be located adjacent to the Waiting Room. | | |
| SERVICES | | | |
| General Requirements | BODY PROTECTED = No | CARDIAC PROTECTED = No | |
| Air | AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No | AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No | |
| Lighting | LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes | LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = Yes | |
| Nurse Call | NURSE CALL SYSTEM = No | | |

Room Fabrics

| AusHFG code | Description | Comment |
|-------------|---|--------------------------------------|
| CLFS-006 | CEILING: plasterboard, flush set, suspended, paint, washable | Drop in tile ceiling also acceptable |
| CLCN-002 | CORNICE: aluminium, 24mm shadow angle, powdercoat | |
| DWSC-003 | DOOR: 910mm c/o, single leaf, solid core, paint | lockable |
| DWPR-003 | DOOR PROTECTION: kickplate, to 300 AFFL, vinyl, prefinished | |
| FLCP-003 | FLOOR FINISH: carpet, broadloom, 48 oz., 90/10 wool/nylon | |
| FLVY-007 | FLOOR FINISH: vinyl, seamless, coved, standard slip resistant | to basin area |
| DWOB-004 | OBSERVATION: internal window, alum/glass, internal blinds, powdercoat | |
| FLSK-009 | SKIRTING: vinyl, feather edged, 150H, prefinished | |
| WLWA-004 | WALL FINISH: paint, acrylic, washable | |
| WLWA-010 | WALL FINISH: splashback, vinyl | to basin, tiles also acceptable |

Fittings, Furniture and Equipment (FF&E) Items

| AusHFG code | Description | Group | Qty | Comment |
|-------------|--------------------------|-------|-----|----------|
| FQGE-002 | ARTWORK | 3 | 1 | optional |
| HYBA-011 | BASIN: handwash, Type C | 1 | 1 | |
| FQCW-016 | BIN: waste, general, 20L | 3 | 1 | to basin |

Room Name | Mortuary - Waiting

Room Number MOR-W

| AusHFG code | Description | Group | Qty | Comment |
|-------------|---|-------|-----|----------|
| FQBS-028 | CHAIR: visitor, clinical areas | 3 | 3 | |
| FIDI-025 | DISPENSER: paper/hand towel | 2 | 1 | to basin |
| FIDI-030 | DISPENSER: soap | 2 | 1 | to basin |
| FIJO-181 | JOINERY UNIT: vanity, single basin | 1 | 1 | to basin |
| FQBS-043 | LOUNGE: 2 seat, 1600 wide | 3 | 1 | |
| FQTA-075 | TABLE: square, 600W, low height | 3 | 1 | |
| HYTP-037 | TAPWARE: mixer, elbow levers | 1 | 1 | to basin |
| ITNE-053 | TELEPHONE: handset, wall mount, handsfree | 3 | 1 | |

Engineering Services

| AusHFG code | Description | Group | Qty | Comment |
|-------------|---------------------------|-------|-----|---------|
| ITSE-006 | BUTTON: duress, fixed | 1 | 1 | |
| ELGP-109 | GPO: single, wall mounted | 1 | 2 | |
| ELBO-015 | SWITCH: light, single | 1 | 1 | |