

Room Name	Neonatal Bay - General Care, 5m2		Room Number NBGC
Revision	3		
Issue Date	20.03.17		
BRIEFING			
Briefed Area	5.00 m ²		
Hours of Operation	24 Hours		
Occupancy	1 baby; 1-2 staff		
Acoustics	Sound attenuation level high, Acoustic privacy is required to perimeter walls.		
Remarks			
Description / Special Requirements	A single bay for the care of well babies away from their mother's bed area which may include treatments such as phototherapy. A staff handwash basin should be provided for each four Neonatal Bays - General Care. An external outlook is required.		
SERVICES			
General Requirements	BODY PROTECTED = Yes	CARDIAC PROTECTED = No	
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No	
Lighting	LIGHTING: colour corrected = Yes LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = No	LIGHTING: dimmable = Yes LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No	
Nurse Call	NURSE CALL SYSTEM = Yes		

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-006	CORNICE: plasterboard, 90mm to match ceiling finish, paint	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLPR-019	WALL PROTECTION: crash rail, at 900 AFFL, prefinished PVC	Equal to Acrovyn
DWWH-005	WINDOW	Essential

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FQBS-001	BASSINET	3	1	
FIHR-019	BRACKET: for suction bottle	2	1	shared between 4 bays
MGFP-002	FLOWMETER: medical air	3	1	shared between 4 bays
MGFP-004	FLOWMETER: oxygen	3	1	optional, shared between 4 bays
MMGE-100	SUCTION BOTTLE	3	1	shared between 4 bays

Engineering Services

Room Name | Neonatal Bay - General Care, 5m2

Room Number NBGC

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	shared between 4 bays
ITCL-008	BUTTON: nurse call, staff assist	1	1	shared between 4 bays
ELGP-209	GPO: double, wall mounted, RCD protected	1	1	shared between 4 bays
ELGP-109	GPO: single, wall mounted	1	2	shared between 2 bays
ELGP-110	GPO: single, wall mounted, cleaner	1	1	to serve a group of bays
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	shared between 4 bays
MGAS-042	OUTLET: oxygen (O2), on services panel	1	1	shared between 4 bays
MGAS-062	OUTLET: suction, on services panel	1	1	shared between 4 bays
MMSP-026	SERVICES PANEL: wall mounted	2	1	