

Room Name | Office - Write-up, 5m2

Room Number OFF-WI-5

Revision 2
Issue Date 20.03.17

BRIEFING
Briefed Area 5.00 m²
Hours of Operation 24 Hours
Occupancy 2 staff members

Acoustics
Remarks
Description / Special Requirements

The Write-up Bay provides a write-up bench for use by members of the patient care team. In this space the User may review and write-up patient records, enter patient data on computer and make telephone calls. If located within the Operating Unit it may also include an optional area for porters to wait until paged or called by staff. The Write-up space must not impede the corridor.

SERVICES
General Requirements

BODY PROTECTED = No CARDIAC PROTECTED = No

Air

 AIRCONDITIONING = Yes AIRCONDITIONING: hepa filtered = No
 AIRCONDITIONING: positive pressure = No AIRCONDITIONING: negative pressure = No
 EXHAUST: room exhaust = No VENTILATION = No

Lighting

 LIGHTING: colour corrected = No LIGHTING: dimmable = No
 LIGHTING: downlights = No LIGHTING: downlights, dimmable = No
 LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No
 LIGHTING: fluorescent, general = Yes LIGHTING: indirect = No

Nurse Call

NURSE CALL SYSTEM = Yes

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLGE-001	CEILING: plasterboard, bulkhead, paint	Between above bench joinery and ceiling
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLPR-010	WALL PROTECTION: corner guards, to 900 AFFL	Align heights of corner guards with other corridor elements

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FIJO-020	BENCH: 600D, open under, laminate finish	1	1	Standing or seating height, refer RLS or project specific requirements
FQCW-016	BIN: waste, general, 20L	3	1	
FQBS-018	CHAIR: office, ergonomic	3	2	For standing height bench, use ergonomic high chair for standing height

Room Name | Office - Write-up, 5m2

Room Number OFF-WI-5

AusHFG code	Description	Group	Qty	Comment
ITNE-007	COMPUTER: desktop, with display screen	3	2	Consider location of harddrive, if below bench add bracket
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	4	Above bench, number to suit layout. Refer to RLS or project specific requirements
ITNE-049	TELEPHONE: handset, desktop	3	2	
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	Between bench and overbench joinery

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITCL-001	ANNUNCIATOR: nurse call	1	1	Located in corridor adjacent, number to suit design
ELGP-208	GPO: double, wall mounted	1	4	2 per workspace
LIFX-008	LIGHT: task light, built in	1	2	For above bench joinery
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	Number of outlets per faceplate as per ICT policy. 1 per workspace
ELBO-015	SWITCH: light, single	1	2	Pelmet lighting