

Room Name	Parenting Room		Room Number PAR
Revision	4		
Issue Date	20.03.17		
BRIEFING			
Briefed Area	6.00 m ²		
Hours of Operation	Available 24 Hours		
Occupancy	Up to 2		
Acoustics	Sound attenuation level high, Acoustic privacy is required.		
Remarks			
Description / Special Requirements	The Parenting Room is provided for parents to feed and change babies, and will provide access for prams. The Parenting Room will be located with other child related facilities and have ready access to a Toilet and Waiting area.		
SERVICES			
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No	
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = Yes	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No	
Lighting	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No	
Nurse Call	NURSE CALL SYSTEM = No		

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWSC-003	DOOR: 910mm c/o, single leaf, solid core, paint	privacy latch
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	To be decided at project level.
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	tiles also acceptable
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	or tiles for tiled floor
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-007	WALL FINISH: splashback	Selection of material to comply with Part D Infection Prevention and Control AusHFG.

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	1	with sink. Length to suit layout, refer RLS or project specific requirements.
FQCW-016	BIN: waste, general, 20L	3	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to sink

Room Name | Parenting Room

Room Number PAR

AusHFG code	Description	Group	Qty	Comment
FIDI-030	DISPENSER: soap	2	1	to sink
FIHR-026	HOOK: coat	1	1	
FQBS-039	LOUNGE: 1 seat	3	1	
FQGE-044	MAT: baby change	3	1	
HYBA-051	SINK: single	1	1	warm water. Tapware: sink mixer, fixture mounted.
HYTP-040	TAPWARE: mixer, sink, accessible	1	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELGP-208	GPO: double, wall mounted	1	1	
ELBO-015	SWITCH: light, single	1	1	