

Room Name	Patient Bay, Emergency - Ambulance Triage		Room Number PBAT
Revision	1		
Issue Date	29.05.2019		
BRIEFING			
Briefed Area	6.50 m ²		
Hours of Operation	24 Hours		
Occupancy	1 patient; 1-2 staff intermittently		
Acoustics			
Remarks			
Description / Special Requirements	A Patient Bed Bay used for assessment of patients on arrival by ambulance to the emergency department Ambulance Triage. The patient bay may be one of a number within the Ambulance Triage area. The patient bay constitutes a component of the Ambulance Triage area; it requires direct access and observation from write up facilities for ambulance, triage and administrative staff. It will also require direct access to a staff handwashing basin. Negative pressure requirements are for general directional airflow only. Air conditioning to be non recirculating.		
SERVICES			
General Requirements	BODY PROTECTED	<input checked="" type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
Air	AIRCONDITIONING	<input type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure <input checked="" type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION <input type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input checked="" type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
Nurse Call	NURSE CALL SYSTEM	<input checked="" type="checkbox"/>	

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	default = set plasterboard; drop in tile ceiling also acceptable
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-025	WALL FINISH: vinyl, to 1200 AFFL	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	1	
FQCW-005	BIN: waste, clinical, 20L	3	1	shared
FIHR-019	BRACKET: for suction bottle	2	1	
FQBS-028	CHAIR: visitor, clinical areas	3	1	
FQGE-009	CURTAIN: bed screen	3	2	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	

Room Name | Patient Bay, Emergency - Ambulance Triage

Room Number PBAT

AusHFG code	Description	Group	Qty	Comment
MGFP-004	FLOWMETER: oxygen	3	1	
MMGE-100	SUCTION BOTTLE	3	1	
FIRT-025	TRACK: curtain, bedscreen, U shaped	1	1	
MMGE-142	TROLLEY: sharps bin	3	1	shared

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITSE-006	BUTTON: duress, fixed	1	1	
ITCL-004	BUTTON: nurse call, emergency	1	1	on services panel + indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	on services panel + indicator button & light
ELGP-122	GPO: emergency power, single, on services panel	1	2	on services panel
ELGP-110	GPO: single, wall mounted, cleaner	1	1	shared between a group of beds
LIFX-030	LIGHT: downlight, recessed, compact fluorescent	1	1	
ITIN-025	OUTLET: data, double RJ45, on services panel	1	1	
MGAS-042	OUTLET: oxygen (O2), on services panel	1	1	
MGAS-062	OUTLET: suction, on services panel	1	1	
ELPR-006	RCD: residual current device	1	1	on service panel
MMSP-026	SERVICES PANEL: wall mounted	1	1	flush mounted
ELBO-015	SWITCH: light, single	1	1	on services panel for examination downlight