

Room Name | Patient Bay - Critical, 24m2
Room Number PBC-24

| AusHFG code | Description | Group | Qty | Comment |
|-------------|---|-------|-----|--------------------------------------|
| FQCW-016 | BIN: waste, general, 20L | 3 | 1 | |
| FQCW-043 | BIN: waste, sharps, on trolley | 3 | 1 | |
| DWWD-007 | BLIND: venetian, integral | 1 | 2 | to windows, controls to both sides |
| FIHR-004 | BRACKET: for display screen, ceiling mounted | 1 | 1 | |
| FIHR-012 | BRACKET: for monitor, cardiac | 3 | 1 | mounted on pendant |
| FIHR-016 | BRACKET: for sharps bin | 2 | 1 | mounted to trolley |
| MMHA-001 | CARRIER: suction bottle | 3 | 1 | mobile |
| FQBS-022 | CHAIR: recliner, clinical | 3 | 1 | patient - intermittent use |
| FQBS-031 | CHAIR: visitor, patient, stackable | 3 | 1 | |
| ITCL-016 | CLOCK: clock system slave, analogue | 1 | 1 | ceiling mounted, master clock system |
| FQGE-009 | CURTAIN: bed screen | 3 | 1 | |
| FIDI-014 | DISPENSER: disposable glove | 2 | 1 | |
| FIDI-025 | DISPENSER: paper/hand towel | 2 | 1 | to basin |
| FIDI-030 | DISPENSER: soap | 2 | 1 | to basin |
| FIDI-031 | DISPENSER: soap antiseptic | 2 | 1 | to basin |
| ITBU-012 | DISPLAY SCREEN: patient entertainment system | 1 | 1 | |
| MMGE-033 | FLOWCHART STAND: mobile | 3 | 1 | |
| MGFP-002 | FLOWMETER: medical air | 3 | 2 | to pendant |
| MGFP-004 | FLOWMETER: oxygen | 3 | 4 | to pendant |
| LIFX-027 | LIGHT: examination, ceiling mounted | 1 | 1 | |
| MMGE-048 | LINEN CARRIER: dirty, single | 3 | 1 | |
| MMHA-030 | MONITOR: patient, cardiac, pendant mounted | 3 | 1 | |
| MMSP-023 | PENDANT: single, power and data | 1 | 1 | |
| MMSP-020 | PENDANT: tandem, wet and dry combination (fixed or adjustable height) | 1 | 1 | |
| MMGE-096 | STATION: dialysis | 1 | 1 | with RO water & tundish drain |
| FQBS-052 | STOOL: mobile, high, adj height | 3 | 1 | for staff |
| MMGE-100 | SUCTION BOTTLE | 3 | 4 | to pendant |
| FQTA-013 | TABLE: overbed | 3 | 1 | |
| HYTP-037 | TAPWARE: mixer, elbow levers | 1 | 1 | to basin |
| ITNE-053 | TELEPHONE: handset, wall mount, handsfree | 3 | 1 | to staff work area |
| FIRT-023 | TRACK: curtain, bedscreen, L shaped | 1 | 1 | |
| FQSM-016 | TROLLEY | 3 | 1 | |
| FIBM-018 | WHITEBOARD: fixed | 2 | 1 | 600mm x 600mm |

Engineering Services

| AusHFG code | Description | Group | Qty | Comment |
|-------------|-------------------------------|-------|-----|---|
| ITCL-004 | BUTTON: nurse call, emergency | 1 | 1 | on tandem pendant, + indicator button & light |

Room Name | Patient Bay - Critical, 24m2

Room Number PBC-24

| AusHFG code | Description | Group | Qty | Comment |
|-------------|--|-------|-----|---|
| ITCL-006 | BUTTON: nurse call, patient to staff | 1 | 1 | on tandem pendant, + indicator button & light |
| ITCL-008 | BUTTON: nurse call, staff assist | 1 | 1 | on tandem pendant, + indicator button & light |
| HYDR-006 | DRAIN: tundish | 1 | 1 | |
| ELGP-204 | GPO: double, on pendant | 1 | 2 | on single pendant |
| ELGP-208 | GPO: double, wall mounted | 1 | 2 | to walls |
| ELGP-223 | GPO: emergency power, double, wall mounted | 1 | 1 | to dialysis station |
| ELGP-121 | GPO: emergency power, single, on pendant | 1 | 12 | on tandem pendant |
| ELGP-101 | GPO: single, ceiling mounted | 1 | 3 | For TV, clock, proc light |
| ELGP-104 | GPO: single, on pendant | 1 | 12 | on tandem pendant |
| ELGP-110 | GPO: single, wall mounted, cleaner | 1 | 1 | |
| ITCL-028 | HANDSET: nurse call, with patient to staff call button | 1 | 1 | on tandem pendant, call button on the handset |
| LIFX-017 | LIGHT: night light | 1 | 1 | |
| ITIN-024 | OUTLET: data, double RJ45, on pendant | 1 | 1 | on tandem pendant |
| ITIN-024 | OUTLET: data, double RJ45, on pendant | 1 | 1 | on single pendant |
| ITIN-026 | OUTLET: data, double RJ45, wall mounted | 1 | 1 | 1 outlet for telephone |
| ITIN-014 | OUTLET: data, single RJ45, on pendant | 1 | 1 | on tandem pendant, for monitor communications with associated cabling and connections; verify outlet type/s with monitor selected |
| ITIN-070 | OUTLET: MATV | 1 | 1 | |
| MGAS-021 | OUTLET: medical air (MA), on pendant | 1 | 2 | on tandem pendant |
| MGAS-041 | OUTLET: oxygen (O2), on pendant | 1 | 4 | on tandem pendant |
| HYTP-015 | OUTLET: reverse osmosis (RO) water | 1 | 1 | |
| MGAS-061 | OUTLET: suction, on pendant | 1 | 4 | on tandem pendant |
| ELPR-006 | RCD: residual current device | 1 | 1 | on tandem pendant |