

Room Name Patient Bay - Critical (Enclosed), 25m²
Room Number PBCE-25

Revision

4

Issue Date

20.03.17

BRIEFING
Briefed Area

 25.00 m²
Hours of Operation

24 Hours

Occupancy

1 patient, 1- visitors, Up to 6-8 staff

Acoustics

Acoustic privacy is required

Remarks
**Description /
Special Requirements**

An enclosed single Bed Bay for a patient requiring critical care nursing and medical treatment, suitable for Levels 5 & 6 health care facilities. Visual access to Staff Station is required. Screen curtains are required for patient privacy. Maximum natural light is required to patient beds.

SERVICES
General Requirements

BODY PROTECTED = No

CARDIAC PROTECTED = Yes

Air

AIRCONDITIONING = Yes

AIRCONDITIONING: hepa filtered = No

AIRCONDITIONING: positive pressure = No

AIRCONDITIONING: negative pressure = No

EXHAUST: room exhaust = No

VENTILATION = No

Lighting

LIGHTING: colour corrected = Yes

LIGHTING: dimmable = No

LIGHTING: downlights = No

LIGHTING: downlights, dimmable = No

LIGHTING: fluorescent downlights = No

LIGHTING: fluorescent, flush with ceiling, tamper proof = No

LIGHTING: fluorescent general = No

LIGHTING: indirect = No

Nurse Call

NURSE CALL SYSTEM = Yes

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-002	DOOR: 910mm c/o, single leaf, half glazed, solid core/glass, paint	additional door to adjoining space optional
DWGL-071	DOOR: triple leaf, sliding, fully glazed, alum/safety glass, powdercoat/paint	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
DWOB-003	OBSERVATION: internal window, alum/glass, double glazed, integral venetian blind, powdercoat	to partition walls
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	to basin
WLPR-002	WALL PROTECTION: bed protection wall panel, composite, laminate finish	
DWWH-005	WINDOW	desirable

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	4	on pendant
HYBA-009	BASIN: handwash, Type A, scrub	1	1	refer to BHWS-A (similar)

Room Name | Patient Bay - Critical (Enclosed), 25m2

Room Number PBCE-25

AusHFG code	Description	Group	Qty	Comment
MMBE-013	BED: patient, ICU, electric	3	1	
FIJO-020	BENCH: 600D, open under, laminate finish	1	1	optional, freestanding
FQCW-004	BIN: waste, clinical, 120L	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	
FQCW-044	BIN: waste, sharps, wall mounted	3	1	mounted on trolley
DWWD-007	BLIND: venetian, integral	1	4	to windows, controls to both sides of internal observation windows
FIHR-004	BRACKET: for display screen, ceiling mounted	1	1	
FIHR-012	BRACKET: for monitor, cardiac	3	1	
FIHR-016	BRACKET: for sharps bin	2	1	mounted on trolley
MMHA-001	CARRIER: suction bottle	3	1	mobile
FQBS-022	CHAIR: recliner, clinical	3	1	patient - intermittent use
FQBS-031	CHAIR: visitor, patient, stackable	3	1	
ITCL-016	CLOCK: clock system slave, analogue	1	1	master clock system
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	1	near basin
FQGE-009	CURTAIN: bed screen	1	1	
FIDI-014	DISPENSER: antiseptic	2	1	near entry
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap and antiseptic	2	1	to basin
ITBU-012	DISPLAY SCREEN: patient entertainment system	1	1	
MMGE-033	FLOWCHART STAND: mobile	3	1	
MGFP-002	FLOWMETER: medical air	3	2	on tandem pendant
MGFP-004	FLOWMETER: oxygen	3	4	on tandem pendant
LIFX-027	LIGHT: examination, ceiling mounted	1	1	
MMGE-048	LINEN CARRIER: dirty, single	3	1	
MMHA-030	MONITOR: patient, cardiac, pendant mounted	3	1	on tandem pendant
MMSP-023	PENDANT: single, power and data	1	1	
MMSP-020	PENDANT: tandem, wet and dry combination (fixed or adjustable height)	1	1	
MMGE-096	STATION: dialysis	1	1	with RO water outlet & tundish drain
FQBS-052	STOOL: mobile, high, adj height	3	1	for staff
MMGE-100	SUCTION BOTTLE	3	4	on pendant
FQTA-013	TABLE: overbed	3	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
ITNE-053	TELEPHONE: handset, wall mount, handsfree	3	1	
FIRT-023	TRACK: curtain, bedscreen, L shaped	1	1	
FQSM-016	TROLLEY	3	1	
FIBM-018	WHITEBOARD: fixed	2	1	600 x 600

RETIRED
29.05.2019

Room Name | Patient Bay - Critical (Enclosed), 25m2

Room Number PBCE-25

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	on tandem pendant, + indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	on tandem pendant, + indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	on tandem pendant, + indicator button & light
HYDR-006	DRAIN: tundish	1	1	
ELGP-204	GPO: double, on pendant	1	2	on single pendant
ELGP-208	GPO: double, wall mounted	1	2	to walls
ELGP-223	GPO: emergency power, double, wall mounted	1	1	dialysis station
ELGP-121	GPO: emergency power, single, on pendant	1	12	on tandem pendant (2-UPS)
ELGP-101	GPO: single, ceiling mounted	1	3	display screen, clock, proc light
ELGP-104	GPO: single, on pendant	1	12	on tandem pendant
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	on tandem pendant, call button on the handset
LIFX-017	LIGHT: night light	1	1	wall washers
ITIN-024	OUTLET: data, double RJ45, on pendant	1	1	on tandem pendant
ITIN-024	OUTLET: data, double RJ45, on pendant	1	1	on single pendant
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	1 outlet for telephone
ITIN-014	OUTLET: data, single RJ45, on pendant	1	1	on tandem pendant, for monitor communications with associated cabling and connections; verify outlet type/s with monitor selected
ITIN-070	OUTLET: MATV	1	1	
MGAS-021	OUTLET: medical air (MA), on pendant	1	2	on tandem pendant
MGAS-041	OUTLET: oxygen (O2), on pendant	1	4	on tandem pendant
HYTP-015	OUTLET: reverse osmosis (RO) water	1	1	
MGAS-061	OUTLET: suction, on pendant	1	4	on tandem pendant
ELPR-006	RCD: residual current device	1	1	on pendant, panel
ELBO-015	SWITCH: light, single	1	1	

RETIRED
29.05.2019