

**Room Name** | Patient Bay - Acute Treatment, 12m2

**Room Number** PBTR-A12

**Revision**

4

**Issue Date**

20.03.17

**BRIEFING**
**Briefed Area**

 12.00 m<sup>2</sup>
**Hours of Operation**

24 Hours

**Occupancy**

1 patient; 1 - 2 staff

**Acoustics**
**Remarks**
**Description /  
Special Requirements**

The Patient Bed Bay Acute Treatment may be used for assessment and treatment of patients with acute conditions and will be located within the Emergency Unit. The Bay may have partition side walls; glazing is recommended. The Patient Bay will have close access to a staff handwashing basin.

**SERVICES**
**General Requirements**

BODY PROTECTED = Yes

CARDIAC PROTECTED = No

**Air**

AIRCONDITIONING = Yes

AIRCONDITIONING: hepa filtered = No

AIRCONDITIONING: positive pressure = No

AIRCONDITIONING: negative pressure = No

EXHAUST: room exhaust = No

VENTILATION = No

**Lighting**

LIGHTING: colour corrected = Yes

LIGHTING: dimmable = No

LIGHTING: downlights = No

LIGHTING: downlights, dimmable = No

LIGHTING: fluorescent, downlights = No

LIGHTING: fluorescent, flush with ceiling, tamper proof = No

LIGHTING: fluorescent, general = No

LIGHTING: indirect = No

**Nurse Call**

NURSE CALL SYSTEM = Yes

**Room Fabrics**

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
DWOB-003	OBSERVATION: internal window, alum/glass, double glazed, integral venetian blind, powdercoat	to partition walls, if provided
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLPR-002	WALL PROTECTION: bed protection wall panel, composite, laminate finish	
WLPR-013	WALL PROTECTION: corner guards, to 1500 AFFL, prefinished PVC	As required, Equal to 'Acrovyn'
WLPR-019	WALL PROTECTION: crash rail, at 900 AFFL, prefinished PVC	As required, Equal to 'Acrovyn'

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	2	
MMBE-014	BED: patient, ICU, electric with mattress	3	1	
FIJO-020	BENCH: 600D, open under, laminate finish	1	1	optional, freestanding
FQSN-006	BIN: storage bins, for wall mounted panel	3	10	optional, for storage on louvred panel

**Room Name** | Patient Bay - Acute Treatment, 12m2

**Room Number** PBTR-A12

AusHFG code	Description	Group	Qty	Comment
FQCW-044	BIN: waste, sharps, wall mounted	3	1	
DWWD-007	BLIND: venetian, integral	1	2	to internal windows if provided
FIHR-011	BRACKET: for monitor	3	1	optional, may have ergonomic arm
FIHR-016	BRACKET: for sharps bin	2	1	
FIHR-019	BRACKET: for suction bottle	2	1	
FQBS-030	CHAIR: visitor, patient	3	1	
FQGE-009	CURTAIN: bed screen	3	1	
MMGE-031	DIAGNOSTIC SET: wall mounted	3	1	optional
FIDI-014	DISPENSER: disposable glove	2	1	
MGFP-002	FLOWMETER: medical air	3	1	
MGFP-004	FLOWMETER: oxygen	3	2	
MMGE-039	HANGER: IV, for ceiling track	1	1	
LIFX-013	LIGHT: procedure, ceiling mounted, small	1	1	
MMHA-008	MONITOR: patient, cardiac with vital signs	3	1	optional
FIHR-033	PANEL: for storage bins, wall mount	1	1	optional, for storage
FIJO-194	SHELF: laminate	1	1	above services panel, optional
MMGE-100	SUCTION BOTTLE	3	1	
FIRT-020	TRACK: ceiling mounted, IV	1	1	
FIRT-024	TRACK: curtain, bedscreen, straight	1	1	
FQSM-016	TROLLEY	3	1	
MMGE-123	TROLLEY: instrument	3	1	

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	on services panel, + indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	on services panel, + indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	on services panel, + indicator button & light
ELGP-206	GPO: double, on services panel, RCD protected	1	1	on services panel
ELGP-122	GPO: emergency power, single, on services panel	1	3	on services panel
ELGP-123	GPO: emergency power, single, wall mounted	1	1	for monitor, if required
ELGP-101	GPO: single, ceiling mounted	1	1	exam light
ELGP-105	GPO: single, on services panel	1	3	on services panel
ELGP-109	GPO: single, wall mounted	1	1	for electric bed
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	call button on the handset
ITIN-025	OUTLET: data, double RJ45, on services panel	1	1	on services panel, 1 outlet for telephone

**Room Name** | Patient Bay - Acute Treatment, 12m2

**Room Number** PBTR-A12

AusHFG code	Description	Group	Qty	Comment
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	optional, if networked monitoring required, with associated cabling; verify outlet type/s with monitor selected
ITIN-070	OUTLET: MATV	1	1	
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	on services panel
MGAS-032	OUTLET: nitrous oxide (N2O), on services panel	1	1	on services panel, optional
MGAS-042	OUTLET: oxygen (O2), on services panel	1	2	on services panel
MGAS-053	OUTLET: scavenge, on services panel	1	1	on services panel, optional, if N2O provided
MGAS-062	OUTLET: suction, on services panel	1	2	on services panel
MMSP-026	SERVICES PANEL: wall mounted	2	1	
ELBO-015	SWITCH: light, single	1	1	