Australasian Health Facility Guidelines

Room Name Patient Room, Emergency - Acute Treatment Special Room Number PBTR-AS

Revision	1			
Issue Date	29.05.2019			
BRIEFING				
Briefed Area	15.00 m ²			
Hours of Operation	24 Hours			
Occupancy	1 patient; 1-2 staff			
Acoustics				
Remarks				
Description / Special Requirements	as a Class S isolation bay and an acute t must be provided in close proximity. It ma environment. An Ensuite is required for C	reatm ay also lass \$	t Special is a multipurpose enclosed treatment space that a ent bay that is accessible for wheelchair users. A patient to be used for paediatric patients in a mixed adult/paediatric and/or paediatric use. With an Ensuite, Anteroom, negative also be used as a Class N Isolation enclosed treatment sp	ilet ′e
	Glazing is recommended to side walls, if	space	planning allows.	bace.
SERVICES	Glazing is recommended to side walls, if	space	planning allows.	
SERVICES General Requirements	Glazing is recommended to side walls, if BODY PROTECTED	space √	planning allows.	
	Glazing is recommended to side walls, if	space	planning allows.	
General Requirements	Glazing is recommended to side walls, if BODY PROTECTED	space √	CARDIAC PROTECTED	
General Requirements	Glazing is recommended to side walls, if BODY PROTECTED AIRCONDITIONING	space V	CARDIAC PROTECTED AIRCONDITIONING: hepa filtered	
General Requirements Air	Glazing is recommended to side walls, if BODY PROTECTED AIRCONDITIONING AIRCONDITIONING: positive pressure	space ☑ ☑	CARDIAC PROTECTED AIRCONDITIONING: hepa filtered AIRCONDITIONING: negative pressure	
General Requirements	Glazing is recommended to side walls, if BODY PROTECTED AIRCONDITIONING AIRCONDITIONING: positive pressure EXHAUST: room exhaust	space ✓ □	CARDIAC PROTECTED AIRCONDITIONING: hepa filtered AIRCONDITIONING: negative pressure VENTILATION	
General Requirements Air	Glazing is recommended to side walls, if BODY PROTECTED AIRCONDITIONING AIRCONDITIONING: positive pressure EXHAUST: room exhaust LIGHTING: colour corrected	space V D	CARDIAC PROTECTED AIRCONDITIONING: hepa filtered AIRCONDITIONING: negative pressure VENTILATION LIGHTING: dimmable	
General Requirements Air	Glazing is recommended to side walls, if BODY PROTECTED AIRCONDITIONING AIRCONDITIONING: positive pressure EXHAUST: room exhaust LIGHTING: colour corrected LIGHTING: downlights	space ✓ ✓ □ □	CARDIAC PROTECTED AIRCONDITIONING: hepa filtered AIRCONDITIONING: negative pressure VENTILATION LIGHTING: dimmable LIGHTING: downlights, dimmable LIGHTING: fluorescent/LED, flush with ceiling, tamper	

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWGL-032	DOOR: 1400mm c/o, 1 1/2 leaf, half glazed, solid core/safety glass, paint	
DWSC-003	DOOR: 910mm c/o, single leaf, solid core, paint	optional
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	floor finish must be minimum slip rating R10; Pendulum P3 or agreed equivalent to extend under basin
DWOB-006	OBSERVATION: internal window, alum/safety glass, double glazed, integral venetian blind, powdercoat	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	
WLWA-025	WALL FINISH: vinyl, to 1200 AFFL	
WLPR-002	WALL PROTECTION: bed protection wall panel, composite, laminate finish	to bedhead wall





Room Name Patient Room, Emergency - Acute Treatment Special Room Number PBTR-AS

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	2	
HYBA-010	BASIN: handwash, Type B	1	1	
MMBE-011	BED: patient, emergency, electric	3	1	
FQSN-006	BIN: storage bins, for wall mounted panel	3	3	
FQCW-005	BIN: waste, clinical, 20L	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	
FQCW-044	BIN: waste, sharps, wall mounted	3	1	
DWWD-007	BLIND: venetian, integral	1	1	to internal window
FIHR-063	BRACKET: for all-in-one computer, with keyboard shelf, wall mounted	2	1	optional
FIHR-067	BRACKET: for monitor, wall mounted, articulated, adj height	2	1	
FIHR-016	BRACKET: for sharps bin	2	1	
FIHR-019	BRACKET: for suction bottle	2	2	
FQBS-030	CHAIR: visitor, patient	3	1	
ITNE-066	COMPUTER: all-in-one, wall mounted	3	1	optional, or workstation on wheels
ITNE-008	COMPUTER: for workstation on wheels	3	1	
FQGE-010	CURTAIN: privacy screen	3	1	
MMGE-031	DIAGNOSTIC SET: wall mounted	2	1	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	
FIDI-030	DISPENSER: soap	2	1	
FIDI-031	DISPENSER: soap antiseptic	2	1	
MGFP-002	FLOWMETER: medical air	3	1	
MGFP-004	FLOWMETER: oxygen	3	2	
ITNE-067	KEYBOARD: keyboard and mouse only	3	1	optional
LIFX-013	LIGHT: procedure, ceiling mounted, small	1	1	
MMHA-005	MONITOR: patient, cardiac	3	1	
FIHR-033	PANEL: for storage bins, wall mount	1	1	
MMGE-100	SUCTION BOTTLE	3	2	
FQTA-013	TABLE: overbed	3	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	
FIRT-041	TRACK: curtain, privacy, U shaped, angled	1	1	
MMGE-164	WORKSTATION ON WHEELS: clinical, mobile	3	1	

Engineering Services





Room Name Patient Room, Emergency - Acute Treatment Special Room Number PBTR-AS

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	on services panel, + indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	on services panel, + indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	on services panel, + indicator button & light
MEEX-008	EXHAUST: low level	1	1	optional, for negative pressure room
ELGP-223	GPO: emergency power, double, wall mounted	1	1	
ELGP-125	GPO: emergency power, single, ceiling mounted	1	1	
ELGP-122	GPO: emergency power, single, on services panel	1	8	
ELGP-123	GPO: emergency power, single, wall mounted	1	3	for monitor, if required
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	
ITIN-025	OUTLET: data, double RJ45, on services panel	1	1	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	for patient monitor and wall mounted PC, if required
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	
MGAS-042	OUTLET: oxygen (O2), on services panel	1	2	
MGAS-062	OUTLET: suction, on services panel	1	2	
ELPR-006	RCD: residual current device	1	2	
MMSP-026	SERVICES PANEL: wall mounted	1	3	
ELBO-012	SWITCH: light, dimmer	1	2	dimmable to allow paediatric patients to sleep