

Room Name	Patient Bay, Emergency - Fast Track		Room Number	PBTR-FT
Revision	1			
Issue Date	29.05.2019			
BRIEFING				
Briefed Area	6.50 m ²			
Hours of Operation	24 Hours			
Occupancy	1 patient; 1-2 staff intermittently			
Acoustics				
Remarks				
Description / Special Requirements	A short stay patient bay used for assessment and treatment of patients with non acute conditions. The patient bay will have close access to a staff handwashing basin and patient toilet.			
SERVICES				
General Requirements	BODY PROTECTED	<input checked="" type="checkbox"/>	CARDIAC PROTECTED	<input type="checkbox"/>
Air	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered	<input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure	<input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION	<input type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input checked="" type="checkbox"/>	LIGHTING: dimmable	<input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable	<input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof	<input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect	<input type="checkbox"/>
Nurse Call	NURSE CALL SYSTEM	<input checked="" type="checkbox"/>		

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-021	WALL FINISH: vinyl, to 1800 AFFL	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	2	
FQSN-006	BIN: storage bins, for wall mounted panel	3	3	
FQCW-016	BIN: waste, general, 20L	3	1	shared
FIHR-019	BRACKET: for suction bottle	2	2	
FQBS-030	CHAIR: visitor, patient	3	1	
MMBE-023	COUCH: examination, electric, mobile	3	1	optional, may be replaced with a patient chair or recliner
FQGE-009	CURTAIN: bed screen	3	2	

Room Name | Patient Bay, Emergency - Fast Track
Room Number PBTR-FT

AusHFG code	Description	Group	Qty	Comment
MMGE-031	DIAGNOSTIC SET: wall mounted	2	1	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-014	DISPENSER: disposable glove	2	1	
MGFP-002	FLOWMETER: medical air	3	1	
MGFP-004	FLOWMETER: oxygen	3	1	
FIHR-026	HOOK: coat	1	2	optional
LIFX-013	LIGHT: procedure, ceiling mounted, small	1	1	
FIHR-033	PANEL: for storage bins, wall mount	1	1	
MMGE-100	SUCTION BOTTLE	3	2	
FIRT-025	TRACK: curtain, bedscreen, U shaped	1	1	
MMGE-142	TROLLEY: sharps bin	3	1	shared

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	on services panel + indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	on services panel + indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	on services panel + indicator button & light
ELGP-125	GPO: emergency power, single, ceiling mounted	1	1	
ELGP-122	GPO: emergency power, single, on services panel	1	4	
ELGP-123	GPO: emergency power, single, wall mounted	1	1	
ELGP-110	GPO: single, wall mounted, cleaner	1	1	shared between a group of beds
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	on services panel, call button on the handset
ITIN-025	OUTLET: data, double RJ45, on services panel	1	1	
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	
MGAS-042	OUTLET: oxygen (O2), on services panel	1	1	
MGAS-062	OUTLET: suction, on services panel	1	2	
ELPR-006	RCD: residual current device	1	1	
MMSP-026	SERVICES PANEL: wall mounted	1	2	
ELBO-015	SWITCH: light, single	1	1	