

Room Name | Patient Bay - Holding, 6m2

Room Number PBTR-H-6

Revision 5
Issue Date 20.03.17

BRIEFING
Briefed Area 6.00 m²
Hours of Operation 24 Hours
Occupancy 1 patient; 1 - 2 staff intermittently
Acoustics
Remarks
Description / Special Requirements

A Patient Bed Bay used for holding of patients prior to procedures, observation of patients following procedures or for assessment and treatment of patients with non acute conditions. The Patient Bay will have close access to a staff handwashing basin. Requirement for services including medical gases and power will be dependant on the use of the bay.

SERVICES
General Requirements

BODY PROTECTED = Yes CARDIAC PROTECTED = No

Air

 AIRCONDITIONING = Yes AIRCONDITIONING: hepa filtered = No
 AIRCONDITIONING: positive pressure = No AIRCONDITIONING: negative pressure = No
 EXHAUST: room exhaust = No VENTILATION = No

Lighting

 LIGHTING: colour corrected = Yes LIGHTING: dimmable = No
 LIGHTING: downlights = Yes LIGHTING: downlights, dimmable = No
 LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No
 LIGHTING: fluorescent, general = No LIGHTING: indirect = No

Nurse Call

NURSE CALL SYSTEM = Yes

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	Default = set plasterboard; drop in tile ceiling also acceptable
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLPR-002	WALL PROTECTION: bed protection wall panel, composite, laminate finish	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	1	required if suction outlet provided
MMBE-011	BED: patient, emergency, electric	3	1	spatial provision required
FQSN-006	BIN: storage bins, for wall mounted panel	3	3	for louvred panel
FIHR-019	BRACKET: for suction bottle	2	1	required if suction outlet provided
FQGE-009	CURTAIN: bed screen	3	1	
MGFP-002	FLOWMETER: medical air	3	1	required if air outlet provided

Room Name | Patient Bay - Holding, 6m2

Room Number PBTR-H-6

AusHFG code	Description	Group	Qty	Comment
MGFP-004	FLOWMETER: oxygen	3	1	required if oxygen outlet provided
LIFX-013	LIGHT: procedure, ceiling mounted, small	1	1	optional
FIHR-033	PANEL: for storage bins, wall mount	1	1	optional
MMGE-100	SUCTION BOTTLE	3	1	required if suction outlet provided
FIRT-025	TRACK: curtain, bedscreen, U shaped	1	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	on services panel + indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	on services panel + indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	on services panel + indicator button & light
ELGP-122	GPO: emergency power, single, on services panel	1	2	on services panel
ELGP-105	GPO: single, on services panel	1	2	on services panel
ELGP-109	GPO: single, wall mounted	1	1	to bedhead, low level for bed
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	on services panel, call button on the handset
ITIN-025	OUTLET: data, double RJ45, on services panel	1	1	on services panel
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	on services panel, optional, dependant on use of the bay
MGAS-042	OUTLET: oxygen (O2), on services panel	1	1	on services panel, optional, dependant on use of the bay
MGAS-062	OUTLET: suction, on services panel	1	1	on services panel, optional, dependant on use of the bay
MMSP-026	SERVICES PANEL: wall mounted	2	1	flush mounted
ELBO-015	SWITCH: light, single	1	1	on services panel