

**Room Name** Patient Bay - Non Acute Treatment, 10m2

**Room Number** PBTR-NA

**Revision**

4

**Issue Date**

20.03.17

**BRIEFING**
**Briefed Area**

 10.00 m<sup>2</sup>
**Hours of Operation**

24 Hours

**Occupancy**

1 patient; 1 - 2 staff intermittently

**Acoustics**
**Remarks**
**Description /  
Special Requirements**

A Patient Bed Bay used for assessment and treatment of patients with non acute conditions. The Patient Bay will have close access to a staff handwashing basin.

**SERVICES**
**General Requirements**

BODY PROTECTED = Yes

CARDIAC PROTECTED = No

**Air**

AIRCONDITIONING = Yes

AIRCONDITIONING: hepa filtered = No

AIRCONDITIONING: positive pressure = No

AIRCONDITIONING: negative pressure = No

EXHAUST: room exhaust = No

VENTILATION = No

**Lighting**

LIGHTING: colour corrected = Yes

LIGHTING: dimmable = No

LIGHTING: downlights = Yes

LIGHTING: downlights, dimmable = No

LIGHTING: fluorescent, downlights = No

LIGHTING: fluorescent, flush with ceiling, tamper proof = No

LIGHTING: fluorescent, general = No

LIGHTING: indirect = No

**Nurse Call**

NURSE CALL SYSTEM = Yes

**Room Fabrics**

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLPR-002	WALL PROTECTION: bed protection wall panel, composite, laminate finish	
WLPR-013	WALL PROTECTION: corner guards, to 1500 AFFL, prefinished PVC	As required, Equal to 'Acrovyn'
WLPR-019	WALL PROTECTION: crash rail, at 900 AFFL, prefinished PVC	As required, equal to 'Acrovyn'

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	1	to services panel
MMBE-014	BED: patient, ICU, electric with mattress	3	1	
FQSN-006	BIN: storage bins, for wall mounted panel	3	3	on louvred panel, if provided
FQCW-043	BIN: waste, sharps, on trolley	3	1	
FQCW-044	BIN: waste, sharps, wall mounted	3	1	
FIHR-016	BRACKET: for sharps bin	2	2	

**Room Name | Patient Bay - Non Acute Treatment, 10m2**
**Room Number PBTR-NA**

AusHFG code	Description	Group	Qty	Comment
FIHR-019	BRACKET: for suction bottle	2	1	
FQBS-030	CHAIR: visitor, patient	3	1	
FQGE-009	CURTAIN: bed screen	3	1	
MMGE-031	DIAGNOSTIC SET: wall mounted	3	1	optional
FIDI-014	DISPENSER: disposable glove	2	1	
MGFP-002	FLOWMETER: medical air	3	1	to services panel
MGFP-004	FLOWMETER: oxygen	3	1	to services panel
LIFX-013	LIGHT: procedure, ceiling mounted, small	1	1	
FIHR-033	PANEL: for storage bins, wall mount	1	1	optional
FIJO-194	SHELF: laminate	1	1	
MMGE-100	SUCTION BOTTLE	3	1	on bracket
FIRT-020	TRACK: ceiling mounted, IV	1	1	
FIRT-024	TRACK: curtain, bedscreen, straight	1	1	
FQSM-016	TROLLEY	3	1	

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	on services panel + indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	on services panel + indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	on services panel + indicator button & light
ELGP-122	GPO: emergency power, single, on services panel	1	3	on service panel
ELGP-101	GPO: single, ceiling mounted	1	1	for light
ELGP-105	GPO: single, on services panel	1	4	on services panel
ELGP-109	GPO: single, wall mounted	1	1	
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	on services panel, call button on the handset
ITIN-025	OUTLET: data, double RJ45, on services panel	1	1	on services panel
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	on services panel
MGAS-042	OUTLET: oxygen (O2), on services panel	1	1	on services panel
MGAS-062	OUTLET: suction, on services panel	1	1	on services panel
MMSP-026	SERVICES PANEL: wall mounted	2	1	