

Room Name Patient Bay - Recovery, Stage 1, 9m2

Room Number PBTR-RS1

Revision

4

Issue Date

02.07.2018

BRIEFING
Briefed Area

 9.00 m²
Hours of Operation

24 Hours

Occupancy

1 patient; 1 staff

Acoustics
Remarks
**Description /
Special Requirements**

A Patient Bed Bay used for the recovery of patients from anaesthetic, located within the Operating Unit or Day Procedures Unit. A clinical handwashing basin will be provided for each 4 Patient Recovery Bays. Bays will require direct observation from the Staff Station. The use of Workstations on Wheels for reporting should be considered when designing clusters of Stage 1 Patient Recovery Bays.

SERVICES
General Requirements

BODY PROTECTED



CARDIAC PROTECTED


Air

AIRCONDITIONING



AIRCONDITIONING: hepa filtered



AIRCONDITIONING: positive pressure



AIRCONDITIONING: negative pressure



EXHAUST: room exhaust



VENTILATION


Lighting

LIGHTING: colour corrected



LIGHTING: dimmable



LIGHTING: downlights



LIGHTING: downlights, dimmable



LIGHTING: fluorescent/LED, downlights



LIGHTING: fluorescent/LED, flush with ceiling, tamper proof



LIGHTING: fluorescent/LED, general



LIGHTING: indirect


Nurse Call

NURSE CALL SYSTEM


Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLPR-001	WALL PROTECTION: bed protection wall panel	
WLPR-010	WALL PROTECTION: corner guards, to 900 AFFL	optional, for low level duct, if provided
DWWH-005	WINDOW	optional but desirable

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	2	
MMBE-010	BED: patient, electric with mattress	3	1	optional: to be provided for day patients only. Inpatients will use own bed.
FQCW-005	BIN: waste, clinical, 20L	3	1	

Room Name | Patient Bay - Recovery, Stage 1, 9m2
Room Number PBTR-RS1

AusHFG code	Description	Group	Qty	Comment
DWWD-007	BLIND: venetian, integral	1	1	optional, required to external window/s if provided
FIHR-068	BRACKET: for alcohol based hand rub, attached to bed	3	1	
FIHR-067	BRACKET: for monitor, wall mounted, articulated, adj height	2	1	
FIHR-019	BRACKET: for suction bottle	2	2	
ITNE-008	COMPUTER: for workstation on wheels	3	1	
FQGE-009	CURTAIN: bed screen	3	2	
FIDI-014	DISPENSER: disposable glove	2	1	
MGFP-002	FLOWMETER: medical air	3	1	
MGFP-004	FLOWMETER: oxygen	3	2	
MMGE-039	HANGER: IV, for ceiling track	1	1	
FIHR-029	HOOK: equipment	1	2	
LIFX-013	LIGHT: procedure, ceiling mounted, small	1	1	LED or other lamp of equivalent colour quality
MMHA-008	MONITOR: patient, cardiac with vital signs	3	1	on bracket
FIHR-033	PANEL: for storage bins, wall mount	1	1	
FIRT-043	RAIL: equipment - horizontal	1	1	provides additional wall protection
MMGE-100	SUCTION BOTTLE	3	2	
FIRT-038	TRACK: ceiling mounted, IV, straight	1	1	
FIRT-023	TRACK: curtain, bedscreen, L shaped	1	2	
MMGE-119	TROLLEY: equipment	3	1	
MMGE-164	WORKSTATION ON WHEELS: clinical, mobile	3	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	on services panel + indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	on services panel + indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	on services panel + indicator button & light
MEEEX-008	EXHAUST: low level	1	1	provision is subject to jurisdictional policy
ELGP-223	GPO: emergency power, double, wall mounted	1	1	
ELGP-122	GPO: emergency power, single, on services panel	1	7	on services panel
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	on services panel, call button on the handset
ITIN-025	OUTLET: data, double RJ45, on services panel	1	1	on services panel
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	on services panel
MGAS-042	OUTLET: oxygen (O2), on services panel	1	2	on services panel
MGAS-062	OUTLET: suction, on services panel	1	2	on services panel

Room Name | Patient Bay - Recovery, Stage 1, 9m2

Room Number PBTR-RS1

AusHFG code	Description	Group	Qty	Comment
ELPR-006	RCD: residual current device	1	1	
MMSP-026	SERVICES PANEL: wall mounted	1	1	
ELBO-015	SWITCH: light, single	1	1	on services panel