

Room Name	Patient Bay, Emergency - Resuscitation		Room Number PBTR-R
<b>Revision</b>	5		
<b>Issue Date</b>	29.05.2019		
<b>BRIEFING</b>			
<b>Briefed Area</b>	25.00 m <sup>2</sup>		
<b>Hours of Operation</b>	24 Hours		
<b>Occupancy</b>	1 patient; 4 - 5 staff		
<b>Acoustics</b>			
<b>Remarks</b>			
<b>Description / Special Requirements</b>	A Patient Bed Bay for assessment, resuscitation and treatment of patients with critical conditions, located within the Emergency Unit. The Bay may have partition side walls and a bench used for preparation and write-up. Resuscitation and diagnostic equipment should be located in close proximity which may include ventilator, cardiac pacemaking equipment, patient sliders and mobile X-ray machine. Accurate control of ambient temperature is required. Lead shielding may be required depending on use of X-ray equipment; to be assessed by Radiation Consultant.		
<b>SERVICES</b>			
<b>General Requirements</b>	BODY PROTECTED	<input checked="" type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
<b>Air</b>	AIRCONDITIONING	<input type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input checked="" type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION <input type="checkbox"/>
<b>Lighting</b>	LIGHTING: colour corrected	<input checked="" type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
<b>Nurse Call</b>	NURSE CALL SYSTEM	<input checked="" type="checkbox"/>	

**Room Fabrics**

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	floor finish must be minimum slip rating R10; Pendulum P3 or agreed equivalent to extend under basin
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	
WLWA-023	WALL FINISH: vinyl, to 2100 AFFL	
WLPR-013	WALL PROTECTION: corner guards, to 1500 AFFL, prefinished PVC	as required
WLPR-019	WALL PROTECTION: crash rail, at 900 AFFL, prefinished PVC	as required

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	3	on pendant
HYBA-009	BASIN: handwash, Type A, scrub	1	1	refer BHWS-A (similar)

**Room Name | Patient Bay, Emergency - Resuscitation**
**Room Number PBTR-R**

AusHFG code	Description	Group	Qty	Comment
MMBE-011	BED: patient, emergency, electric	3	1	
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	1	open under part
FQCW-005	BIN: waste, clinical, 20L	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	
FQCW-043	BIN: waste, sharps, on trolley	3	1	
FIHR-075	BRACKET: for computer CPU, underdesk mounted	2	1	
FIHR-004	BRACKET: for display screen, ceiling mounted	1	1	optional, for slave display screen
FIHR-076	BRACKET: for display screen, triple, desk mounted	3	1	
FIHR-006	BRACKET: for display screen, wall mounted	2	1	optional, for slave display screen
FIHR-077	BRACKET: for observation camera, ceiling mounted	2	1	
FIJO-099	CAC: cable access cap	3	1	
ITCL-012	CAMERA: observation	2	2	optional, for telemedicine
ITCL-020	CLOCK: clock system slave, dual digital / elapsed time	1	1	
ITNE-008	COMPUTER: for workstation on wheels	3	1	
ITNE-068	COMPUTER: hi performance, for clinical / PACS use, CPU, underbench mount	3	1	
FIJO-216	CUPBOARD: pigeon holes, under bench	1	1	
FQGE-010	CURTAIN: privacy screen	3	2	
MMHA-002	DEFIBRILLATOR	3	1	on resuscitation trolley
MMGE-175	DIAGNOSTIC SET: pendant mounted	2	1	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-021	DISPENSER: mask	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
ITNE-063	DISPLAY SCREEN: for computer	3	1	for patient management system
ITNE-070	DISPLAY SCREEN: PACS	3	2	
MMGE-032	DISPLAY SCREEN: slave, for patient monitor	3	2	optional, one to wall, one to ceiling
MGFP-002	FLOWMETER: medical air	3	1	on pendant
MGFP-004	FLOWMETER: oxygen	3	3	on pendant
MMGE-036	FRIDGE: drugs, underbench	3	1	optional, where more than one resuscitation bay may be centrally located
MMGE-039	HANGER: IV, for ceiling track	1	1	
ITNE-067	KEYBOARD: keyboard and mouse only	3	1	
MMSP-037	LIGHT: operating, single, 550 diam nom. pendant mounted	2	1	
MMGE-048	LINEN CARRIER: dirty, single	3	1	

**Room Name | Patient Bay, Emergency - Resuscitation**
**Room Number PBTR-R**

AusHFG code	Description	Group	Qty	Comment
MMHA-030	MONITOR: patient, cardiac, pendant mounted	3	1	
FQSM-003	PEDESTAL: mobile, wire basket unit, 840H	3	2	
MMSP-018	PENDANT: single, wet and dry combination (fixed or adjustable height)	2	1	
MMGE-176	PUMP: infusion, pendant mounted	3	1	
MMGE-177	PUMP: syringe, pendant mounted	3	1	
MMGE-088	SAFE: dangerous drugs, small	1	1	optional, where more than one resuscitation bay may be centrally located
FQBS-052	STOOL: mobile, high, adj height	3	1	
MMGE-100	SUCTION BOTTLE	3	3	on pendant
HYTP-037	TAPWARE: mixer, elbow levers	1	1	
ITNE-049	TELEPHONE: handset, desktop	3	1	to bench
FIRT-020	TRACK: ceiling mounted, IV	1	1	
FIRT-032	TRACK: curtain, privacy, L shaped	1	1	
MMGE-126	TROLLEY: intubation	3	1	
FQSM-043	TROLLEY: nested, set of 3, underbench	3	1	
MMHA-027	TROLLEY: resuscitation, adult	3	1	where more than one resuscitation bay may be centrally located
FQSM-039	TROLLEY: waste bag	3	1	
MMHA-023	VENTILATOR	3	1	on pendant
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	
MMGE-164	WORKSTATION ON WHEELS: clinical, mobile	3	1	

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	on pendant + indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	on pendant + indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	on pendant + indicator button & light
ITCL-023	CONTROL PANEL: master clock system	1	1	
ELGP-223	GPO: emergency power, double, wall mounted	1	5	one to resus. trolley
ELGP-121	GPO: emergency power, single, on pendant	1	8	on pendant
ELGP-123	GPO: emergency power, single, wall mounted	1	5	
ELGP-123.1	GPO: emergency power, single, wall mounted (V)	1	1	optional, for optional drug fridge
ELGP-110	GPO: single, wall mounted, cleaner	1	2	
ELGP-132	GPO: UPS, single, on pendant	1	4	
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	call button on the handset
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	

**Room Name** | Patient Bay, Emergency - Resuscitation

**Room Number** PBTR-R

AusHFG code	Description	Group	Qty	Comment
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	4	optional, where supplying data to drug fridge and slave display screens
ITIN-034	OUTLET: data, triple RJ45, on pendant	1	2	
MGAS-021	OUTLET: medical air (MA), on pendant	1	1	on pendant
MGAS-031	OUTLET: nitrous oxide (N2O), on pendant	1	1	optional, on pendant
MGAS-041	OUTLET: oxygen (O2), on pendant	1	3	on pendant
MGAS-051	OUTLET: scavenge, on pendant	1	1	optional, on pendant, if N2O provided
MGAS-061	OUTLET: suction, on pendant	1	3	on pendant
ELPR-006	RCD: residual current device	1	2	
ELBO-015	SWITCH: light, single	1	1	
ELPR-007	UPS: status indicator	1	1	