

Room Name	Pharmacy - Distribution Workstation		Room Number PHA-DB
Revision	1		
Issue Date	26.04.2021		
BRIEFING			
Briefed Area	6.00 m ²		
Hours of Operation	8am to 8pm, daily		
Occupancy	1 staff		
Acoustics			
Remarks			
Description / Special Requirements	<p>The Distribution Workstation provides workspace to sort and process dispensed medications to be distributed from the Pharmacy to clinical units (e.g. imprest medications) and may be used to prepare specialised packs (e.g. resuscitation trolley supplies).</p> <p>Additional Considerations:</p> <ul style="list-style-type: none"> • Ready access to bulk store and refrigerated storage is required from this area. • Direct access to a dispatch/collection area is required for holding items prior to delivery. • Printer and telephone facilities to be shared between multiple workstations. A Multifunction device is to be in close proximity to the distribution area. • Ensure adequate lighting over workspace. 		
SERVICES			
Electrical	BODY PROTECTED	<input type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
HVAC	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION <input type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
Security / Nurse Call	NURSE CALL SYSTEM	<input type="checkbox"/>	

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-009	CORNICE: wall trim fixing	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
ITNE-072	BAR CODING: PDE dock	3	1	may be shared between multiple workstations
ITNE-003	BAR CODING: reader	3	1	

Room Name | Pharmacy - Distribution Workstation
Room Number PHA-DB

AusHFG code	Description	Group	Qty	Comment
FIJO-069	BENCH TOP: 750D, joinery under, laminate finish	1	1	
FQBS-018	CHAIR: office, ergonomic	3	1	
ITNE-007	COMPUTER: desktop, with display screen	3	1	may be on wall or desk mounted bracket, an additional screen may be provided depending on project ICT requirements
FIJO-108	CUPBOARD: drawer unit, baskets, 3 x Wire (400mm wide)	1	1	
FQDW-002	DESK: adj height, 1800W x 750D x 750H nom.	3	1	
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	optional

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELGP-223	GPO: emergency power, double, wall mounted	1	2	extent of emergency power to be determined based on service requirements
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	