

Room Name	Pharmacy - Dispensing Workstation		Room Number PHA-DS
<b>Revision</b>	1		
<b>Issue Date</b>	26.04.2021		
<b>BRIEFING</b>			
<b>Briefed Area</b>	4.00 m <sup>2</sup>		
<b>Hours of Operation</b>	8am to 8pm, daily		
<b>Occupancy</b>	1 staff		
<b>Acoustics</b>			
<b>Remarks</b>			
<b>Description / Special Requirements</b>	<p>The Dispensing Workstation provides workspace to prepare, assemble and label patient medications for dispensing to inpatients and outpatients. The workstations can be configured to provide dispensing/assembly stations and a checking station as required.</p> <p>Dispensing workstations should be arranged to support effective workflows, reduce travel time and avoid error. These stations should be arranged such that extended reaches are avoided. Where dispensing workstations are arranged adjacent to each other, corridors in between them should be wide enough to provide unobstructed movement for staff and trolleys.</p> <p>Additional Considerations:</p> <ul style="list-style-type: none"> <li>• Ready access to the bulk store and refrigerated storage is required.</li> <li>• Printer and telephone facilities to be shared between multiple workstations. A Multifunction device is to be in close proximity to the dispensing area.</li> <li>• Ensure adequate lighting over workspace - task lighting may be required.</li> </ul>		
<b>SERVICES</b>			
<b>Electrical</b>	BODY PROTECTED	<input type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
<b>HVAC</b>	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION <input type="checkbox"/>
<b>Lighting</b>	LIGHTING: colour corrected	<input type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
<b>Security / Nurse Call</b>	NURSE CALL SYSTEM	<input type="checkbox"/>	

**Room Fabrics**

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-009	CORNICE: wall trim fixing	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
ITNE-003	BAR CODING: reader	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	quantity and type of bins to be based on local waste management policies

**Room Name | Pharmacy - Dispensing Workstation**
**Room Number PHA-DS**

AusHFG code	Description	Group	Qty	Comment
FQCW-064	BIN: waste, paper, secure, 20L	3	1	quantity and type of bins to be based on local waste management policies
FQBS-019	CHAIR: office, ergonomic, high	3	1	
ITNE-007	COMPUTER: desktop, with display screen	3	1	may be on desk mounted bracket
ITNE-063	DISPLAY SCREEN: for computer	3	1	optional, depending on project ICT requirements; may be on desk mounted bracket
FQGE-093	PRINTER: desktop, labels, pharmacy	3	1	
FQDW-047	WORKSTATION: pharmacy, services spine bench	3	1	services spine may be shared between multiple workstations
FQDW-048	WORKSTATION: pharmacy, services spine shelves	3	1	services spine may be shared between multiple workstations
FQDW-046	WORKSTATION: pharmacy, straight, adj height, 1800W x 750D x 900H nom.	3	1	

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ELGP-208	GPO: double, wall mounted	1	1	
ELGP-223	GPO: emergency power, double, wall mounted	1	2	extent of emergency power to be determined based on service requirements
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	