

Room Name	Plaster Room	Room Number PLST
<b>Revision</b>	4	
<b>Issue Date</b>	20.03.17	
<b>BRIEFING</b>		
<b>Briefed Area</b>	14.00 m <sup>2</sup>	
<b>Hours of Operation</b>	24 Hours	
<b>Occupancy</b>	1 patient; 2 -3 staff	
<b>Acoustics</b>	Sound attenuation level - high; acoustic privacy is required	
<b>Remarks</b>		
<b>Description / Special Requirements</b>	The Plaster Room allows for the application of Plaster of Paris, or other splints, and for the closed reduction of displaced fractures or dislocations under sedative or regional anaesthesia. Typically a dedicated room provided for high volume services, otherwise, a generic Treatment Room may be used with the inclusion of a plaster trap and other specific plastering equipment.	
<b>SERVICES</b>		
<b>General Requirements</b>	BODY PROTECTED = Yes	CARDIAC PROTECTED = No
<b>Air</b>	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No
<b>Lighting</b>	LIGHTING: colour corrected = Yes LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = No	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No
<b>Nurse Call</b>	NURSE CALL SYSTEM = Yes	

**Room Fabrics**

AusHFG code	Description	Comment
CLGE-001	CEILING: plasterboard, bulkhead, paint	Between above bench joinery and ceiling.
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-033	DOOR: 1400mm c/o, 1 1/2 leaf, observation panel, solid core/glass, paint	sliding cover to glazing
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	To be decided at project level.
FLVY-003	FLOOR FINISH: vinyl, seamless, coved, non slip	Under basin. Significant change in colour to be avoided
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-007	WALL FINISH: splashback	Selection of material to comply with Part D Infection Prevention and Control AusHFG.
WLPR-001	WALL PROTECTION: bed protection wall panel	or similar
WLPR-021	WALL PROTECTION: crash rail, at 900 AFFL	

**Fittings, Furniture and Equipment (FF&E) Items**

**Room Name | Plaster Room**
**Room Number PLST**

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	elbow action levers or handsfree optional.
MMBE-010	BED: patient, electric with mattress	3	1	
FIJO-060	BENCH TOP: 600D, joinery under, stainless steel lipped	1	1	With SS sink and wet edge. Length to suit layout, refer RLS or project specific requirements.
FQCW-016	BIN: waste, general, 20L	3	2	
FQCW-044	BIN: waste, sharps, wall mounted	3	1	
FIHR-016	BRACKET: for sharps bin	2	1	
FIHR-019	BRACKET: for suction bottle	2	1	
ITNE-007	COMPUTER: desktop, with display screen	3	1	On bench, flatscreen, or wall mounted. If wall mounted add bracket. PACS images may be viewed, refer specific project requirements.
FIJO-116	CUPBOARD: tall, double door, adj shelves	1	1	Number to suit layout, refer RLS or project specific requirements.
FIJO-136	CUPBOARD: underbench, double door, adj shelves, lockable	1	1	Number to suit layout, refer RLS or project specific requirements.
FIJO-141	CUPBOARD: underbench, single door, adj shelves, lockable	1	1	Number to suit layout, refer RLS or project specific requirements.
FIJO-145	CUPBOARD: wall mount, double door, adj shelves, lockable	1	1	Number to suit layout, refer RLS or project specific requirements.
FIJO-157	CUPBOARD: wall mount, single door, adj shelves, lockable	1	1	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-014	DISPENSER: disposable glove	2	1	to basin
FIDI-022	DISPENSER: moisturiser	2	1	to hand basin. Depends on operational policy.
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
MGFP-002	FLOWMETER: medical air	3	1	
MGFP-004	FLOWMETER: oxygen	3	1	
LIFX-027	LIGHT: examination, ceiling mounted	1	1	
MMAH-023	SAW: plaster	3	1	
HYBA-053	SINK: single, 450 x 350 x 300D	1	1	hot water; tapware, long lever, wall mounted
MMGE-100	SUCTION BOTTLE	3	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to sink
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin, handsfree optional
ITNE-053	TELEPHONE: handset, wall mount, handsfree	3	1	
HYDR-008	TRAP: plaster	1	1	under sink, mobile
MMAH-028	TROLLEY: plaster	3	1	

**Room Name** | **Plaster Room**
**Room Number** **PLST**
**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ITSE-006	BUTTON: duress, fixed	1	1	optional in ambulatory care area
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	+ indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	+ indicator button & light
ELGP-208	GPO: double, wall mounted	1	3	to walls, bench
ELGP-122	GPO: emergency power, single, on services panel	1	2	
ELGP-105	GPO: single, on services panel	1	4	
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	call button on the handset
LIFX-008	LIGHT: task light, built in	1	1	
ITIN-025	OUTLET: data, double RJ45, on services panel	1	2	
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	wall mounted telephone
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	
MGAS-032	OUTLET: nitrous oxide (N2O), on services panel	1	1	Optional.
MGAS-042	OUTLET: oxygen (O2), on services panel	1	1	
MGAS-053	OUTLET: scavenge, on services panel	1	1	If nitrous required.
MGAS-062	OUTLET: suction, on services panel	1	1	
MMSP-026	SERVICES PANEL: wall mounted	2	1	
ELBO-015	SWITCH: light, single	1	2	task light and room
ELBO-015	SWITCH: light, single	1	1	on services panel