

Room Name	Preparation/ Set-up Room (Imaging)	Room Number PREP-S
Revision	3	
Issue Date	20.03.17	
BRIEFING		
Briefed Area	9.00 m ²	
Hours of Operation	24 Hours	
Occupancy	1 - 2 intermittently	
Acoustics		
Remarks		
Description / Special Requirements	A room for the storage and preparation of opaque radiological media, and where set-up for procedures is undertaken.	
SERVICES		
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No
Lighting	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No
Nurse Call	NURSE CALL SYSTEM = No	

RETIRED

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	lockable
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	equal to Acrovyn
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	equal to Acrovyn
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	tiles also acceptable
WLWA-020	WALL FINISH: vinyl, to 1500 AFFL	tiles also acceptable

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	2	with inset sink
FQCW-016	BIN: waste, general, 20L	3	1	
FQCW-044	BIN: waste, sharps, wall mounted	3	1	

Room Name | Preparation/ Set-up Room (Imaging)
Room Number PREP-S

AusHFG code	Description	Group	Qty	Comment
FIHR-016	BRACKET: for sharps bin	2	1	
FIJO-117	CUPBOARD: tall, double door, adj shelves, lockable	1	1	
FIJO-135	CUPBOARD: underbench, double door, adj shelves	1	2	
FIJO-140	CUPBOARD: underbench, single door, adj shelves	1	1	
FIJO-145	CUPBOARD: wall mount, double door, adj shelves, lockable	1	3	over bench
FIJO-157	CUPBOARD: wall mount, single door, adj shelves, lockable	1	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to hand basin
FIDI-030	DISPENSER: soap	2	1	to hand basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to hand basin
MMGE-036	FRIDGE: drugs, underbench	3	1	optional
FIHR-033	PANEL: for storage bins, wall mount	1	2	above bench, optional
HYBA-070	SINK: single, with drainer, 930mmL, left bowl	1	1	hot water
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
HYTP-040	TAPWARE: mixer, sink, accessible	1	1	
ITNE-049	TELEPHONE: handset, desktop	3	1	optional, on bench

Engineering Services

RETIRED

AusHFG code	Description	Group	Qty	Comment
ELGP-109	GPO: single, wall mounted			
ELGP-109	GPO: single, wall mounted	1	1	Refrigerator, under bench
LIFX-008	LIGHT: task light, built in	1	2	under O/H cupboards
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	
ELBO-015	SWITCH: light, single	1	2	