

Room Name | Procedure Room, 16m2

Room Number PROC-16

Revision 4
Issue Date 20.03.17

BRIEFING

Briefed Area 16.00 m²
Hours of Operation 24 Hours
Occupancy 1 patient; 2 - 4 staff
Acoustics Sound attenuation level medium, Acoustic privacy is required.
Remarks
Description / Special Requirements The Procedure Room may be provided for the performance of procedures that do not require the full facilities of the Operating Suite. This may include suturing or wounds, complex dressings, lumbar puncture, catheterisations, administration of local anaesthesia and use of medical gases in connection with the procedures being performed. General anaesthesia will not be administered in this room.

SERVICES

General Requirements BODY PROTECTED = No CARDIAC PROTECTED = Yes
Air AIRCONDITIONING = Yes AIRCONDITIONING: hepa filtered = No
 AIRCONDITIONING: positive pressure = No AIRCONDITIONING: negative pressure = No
 EXHAUST: room exhaust = No VENTILATION = No
Lighting LIGHTING: colour corrected = Yes LIGHTING: dimmable = No
 LIGHTING: downlights = No LIGHTING: downlights, dimmable = No
 LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No
 LIGHTING: fluorescent, general = No LIGHTING: indirect = No
Nurse Call NURSE CALL SYSTEM = Yes

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-033	DOOR: 1400mm c/o, 1 1/2 leaf, observation panel, solid core/glass, paint	cover to glazing
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	optional door to Clean Utility
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	equal to 'Acrovyn'
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	equal to 'Acrovyn'
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-020	WALL FINISH: vinyl, to 1500 AFFL	
WLPR-002	WALL PROTECTION: bed protection wall panel, composite, laminate finish	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	2	
HYBA-009	BASIN: handwash, Type A, scrub	1	1	refer BHWS-A (similar)
MMBE-009	BED: patient, electric	3	0	space required only

Room Name | Procedure Room, 16m2

Room Number PROC-16

AusHFG code	Description	Group	Qty	Comment
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	1	optional
FQCW-016	BIN: waste, general, 20L	3	1	to basin
FQCW-044	BIN: waste, sharps, wall mounted	3	1	wall mounted, or on trolley
FIHR-016	BRACKET: for sharps bin	2	1	
FIHR-019	BRACKET: for suction bottle	2	2	
ITCL-014	CLOCK: analogue, electric	1	1	
FIJO-136	CUPBOARD: underbench, double door, adj shelves, lockable	1	1	optional
FIJO-145	CUPBOARD: wall mount, double door, adj shelves, lockable	1	1	optional; over bench
FQGE-009	CURTAIN: bed screen	3	1	to door opening
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
MGFP-002	FLOWMETER: medical air	3	1	
MGFP-004	FLOWMETER: oxygen	3	2	
MMGE-036	FRIDGE: drugs, underbench	3	1	optional
LIFX-014	LIGHT: procedure, ceiling mounted	1	1	
MMHA-008	MONITOR: patient, cardiac with vital signs	3	1	optional
FIJO-194	SHELF: laminate	1	1	for monitor, or bracket, optional
MMGE-100	SUCTION BOTTLE	3	2	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	
ITNE-050	TELEPHONE: handset, desktop, handsfree	3	1	
FIRT-021	TRACK: curtain, bedscreen	1	1	to door opening
FQSM-016	TROLLEY	3	1	instrument / procedure
MMGE-152	VIEWER: X-ray, 2 screen	1	1	recessed

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	+ indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	+ indicator button & light
ELGP-208	GPO: double, wall mounted	1	2	
ELGP-122	GPO: emergency power, single, on services panel	1	3	1 for monitor
ELGP-105	GPO: single, on services panel	1	4	
ELGP-106	GPO: single, special, for equipment	1	4	clock, XRV, light, fridge
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	+ light switch on the handset
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	

Room Name | Procedure Room, 16m2

Room Number PROC-16

AusHFG code	Description	Group	Qty	Comment
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	for monitor communications with associated cabling and connections; verify outlet type/s with monitor selected
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	
MGAS-032	OUTLET: nitrous oxide (N2O), on services panel	1	1	optional
MGAS-042	OUTLET: oxygen (O2), on services panel	1	2	
MGAS-054	OUTLET: scavenge, on services panel, with adapter	1	1	if N2O provided
MGAS-062	OUTLET: suction, on services panel	1	2	
ELPR-006	RCD: residual current device	1	1	
MMSP-026	SERVICES PANEL: wall mounted	2	1	