

Room Name	Procedure Room, 20m2		Room Number PROC-20
Revision	5		
Issue Date	20.03.17		
BRIEFING			
Briefed Area	20.00 m ²		
Hours of Operation	24 Hours		
Occupancy	1 patient; 2-4 staff		
Acoustics	Sound attenuation level - High. Acoustic privacy is required.		
Remarks			
Description / Special Requirements	The Procedure Room may be required for the performance of procedures that do not require the full facilities of the Operating Suite. This may include suturing or wounds, dressings, administration of local anaesthesia and use of medical gases in connection with the procedures being performed. General anaesthesia will not be administered in this room. Additional Design Considerations: Lead shielding may be required depending on use of mobile Imaging equipment. Treatment of bariatric patients including mobile, bariatric lifter access.		
SERVICES			
General Requirements	BODY PROTECTED = Yes	CARDIAC PROTECTED = No	
Air	AIRCONDITIONING = Yes	AIRCONDITIONING: hepa filtered = No	
	AIRCONDITIONING: positive pressure = No	AIRCONDITIONING: negative pressure = No	
	EXHAUST: room exhaust = No	VENTILATION = No	
Lighting	LIGHTING: colour corrected = Yes	LIGHTING: dimmable = No	
	LIGHTING: downlights = No	LIGHTING: downlights, dimmable = No	
	LIGHTING: fluorescent, downlights = No	LIGHTING: fluorescent, flush with ceiling, tamper proof = No	
	LIGHTING: fluorescent, general = No	LIGHTING: indirect = No	
Nurse Call	NURSE CALL SYSTEM = Yes		

Room Fabrics

AusHFG code	Description	Comment
CLGE-001	CEILING: plasterboard, bulkhead, paint	Between above bench joinery and ceiling.
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-007	CORNICE: plasterboard, flush coved between wall and ceiling, paint	
DWGL-033	DOOR: 1400mm c/o, 1 1/2 leaf, observation panel, solid core/glass, paint	Cover to glazing.
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	Optional. To be decided at project level.
FLVY-004	FLOOR FINISH: vinyl, seamless, coved, non-slip, safety	Under basin. Significant change in colour to be avoided.
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-007	WALL FINISH: splashback	Selection of material to comply with Part D Infection Prevention and Control AusHFG.
WLPR-001	WALL PROTECTION: bed protection wall panel	or similar
DWWH-005	WINDOW	optional

Room Name | Procedure Room, 20m2

Room Number PROC-20

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-001	ADAPTER: scavenge	3	1	
MMGE-002	ADAPTER: suction	3	2	
HYBA-009	BASIN: handwash, Type A, scrub	1	1	elbow action levers or handsfree optional.
MMBE-010	BED: patient, electric with mattress	3	1	
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	1	Optional . Length to suit layout, refer RLS or project specific requirements.
FQCW-016	BIN: waste, general, 20L	3	1	
FQCW-044	BIN: waste, sharps, wall mounted	3	1	wall mounted
DWWD-003	BLIND: integral	1	1	Optional, to external windows. Number to suit window configuration.
FIHR-011	BRACKET: for monitor	3	1	
FIHR-016	BRACKET: for sharps bin	2	1	
FIHR-019	BRACKET: for suction bottle	2	2	
ITCL-014	CLOCK: analogue, electric	1	1	
ITNE-007	COMPUTER: desktop, with display screen	3	1	On bench or wall mounted, optional. If wall mounted add bracket. PACS images may be viewed, refer specific project requirements.
FIJO-116	CUPBOARD: tall, double door, adj shelves	1	1	Optional, lockable. Number to suit layout.
FIJO-136	CUPBOARD: underbench, double door, adj shelves, lockable	1	2	adjustable shelf, optional. Number to suit layout, refer RLS or project specific requirements. Storage solution for consumables and equipment to meet project specific Infection Control and WH&S requirements.
FIJO-145	CUPBOARD: wall mount, double door, adj shelves, lockable	1	2	over bench, adjustable shelf, optional. Number to suit layout, refer RLS or project specific requirements. Storage solution for consumables and equipment to meet project specific Infection Control and WH&S requirements.
FQGE-009	CURTAIN: bed screen	3	1	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-022	DISPENSER: moisturiser	2	1	to hand basin. Depends on operational policy.
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
MGFP-002	FLOWMETER: medical air	3	1	
MGFP-004	FLOWMETER: oxygen	3	2	

Room Name | Procedure Room, 20m2
Room Number PROC-20

AusHFG code	Description	Group	Qty	Comment
LIFX-013	LIGHT: procedure, ceiling mounted, small	1	1	
MMHA-008	MONITOR: patient, cardiac with vital signs	3	1	optional
FQBS-052	STOOL: mobile, high, adj height	3	1	
MMGE-100	SUCTION BOTTLE	3	2	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
ITNE-050	TELEPHONE: handset, desktop, handsfree	3	1	to bench or wall mounted
FIRT-026	TRACK: curtain, bedscreen, Z shape	1	1	to door opening
MMGE-119	TROLLEY: equipment	3	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITSE-006	BUTTON: duress, fixed	1	1	optional in ambulatory care area
ITCL-004	BUTTON: nurse call, emergency	1	1	on services panel + indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	on services panel + indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	on services panel
ELGP-208	GPO: double, wall mounted	1	3	to bench, computer PC + spare.
ELGP-122	GPO: emergency power, single, on services panel	1	3	on services panel
ELGP-123	GPO: emergency power, single, wall mounted	1	1	for monitor
ELGP-105	GPO: single, on services panel	1	3	on services panel
ELGP-109	GPO: single, wall mounted	1	2	low level for optional bed or exam couch, clock
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	on services panel, call button on the handset
ITIN-025	OUTLET: data, double RJ45, on services panel	1	1	on services panel
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	for monitor communications with associated cabling and connections; verify outlet type/s with monitor selected
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	on services panel
MGAS-032	OUTLET: nitrous oxide (N2O), on services panel	1	1	on services panel, optional
MGAS-042	OUTLET: oxygen (O2), on services panel	1	2	on services panel
MGAS-053	OUTLET: scavenge, on services panel	1	1	on services panel, optional, if N2O required
MGAS-062	OUTLET: suction, on services panel	1	2	on services panel
MMSP-026	SERVICES PANEL: wall mounted	2	1	
ELBO-015	SWITCH: light, single	1	2	