

Room Name	Procedure Room	Room Number	PROC
Revision	6		
Issue Date	18.01.2021		
BRIEFING			
Briefed Area	20.00 m ²		
Hours of Operation	24 Hours		
Occupancy	1 patient; 2-4 staff		
Acoustics	Sound attenuation level - High. Acoustic privacy is required.		
Remarks			
Description / Special Requirements	<p>The Procedure Room provides a controlled environment and facilities for carrying out procedures that do not require the full facilities of the Operating Suite. This may include suturing of wounds, complex dressings, lumbar puncture, catheterisations, administration of local anaesthesia and use of medical gases in connection with the procedures being performed. General anaesthesia will not be administered in this room. Additional Design Considerations: Lead shielding may be required depending on use of mobile imaging equipment. Treatment of bariatric patients including mobile, bariatric lifter access. The ceiling height has been nominally shown at 3000mm, however 2700mm is also acceptable and the height is to be determined based on ceiling mounted equipment and operational requirements.</p>		
SERVICES			
General Requirements	BODY PROTECTED	<input checked="" type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
Air	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION <input type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input checked="" type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
Nurse Call	NURSE CALL SYSTEM	<input checked="" type="checkbox"/>	

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWGL-033	DOOR: 1400mm c/o, 1 1/2 leaf, observation panel, solid core/glass, paint	
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	floor finish must be minimum slip rating R10; Pendulum P3 or agreed equivalent to extend under basin or inset section of non-slip vinyl required
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-007	WALL FINISH: splashback	to basin
WLWA-020	WALL FINISH: vinyl, to 1500 AFFL	

Fittings, Furniture and Equipment (FF&E) Items

Room Name | Procedure Room
Room Number PROC

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	2	quantity to suit number of suction outlets
HYBA-009	BASIN: handwash, Type A, scrub	1	1	
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	1	
FQCW-008	BIN: waste, clinical, 50L	3	1	optional; type, size and quantity of bins to be determined based on service requirements and waste management policies
FQCW-016	BIN: waste, general, 20L	3	1	to basin
FQCW-043	BIN: waste, sharps, on trolley	3	1	
FIHR-011	BRACKET: for monitor, wall mounted	2	1	optional, for cardiac/vital signs monitor
FIHR-016	BRACKET: for sharps bin	2	1	
FIHR-019	BRACKET: for suction bottle	2	2	quantity to suit number of suction outlets
FIJO-212	BULKHEAD: joinery	1	1	plasterboard bulkhead also acceptable
ITCL-014	CLOCK: analogue, electric	1	1	
ITNE-008	COMPUTER: for workstation on wheels	3	1	computer may alternatively be on benchtop or wall mounted; allocation of WOWs across department to be rationalised
FIJO-135	CUPBOARD: underbench, double door, adj shelves	1	1	
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	1	
FQGE-010	CURTAIN: privacy screen	3	1	
MMGE-031	DIAGNOSTIC SET: wall mounted	2	1	optional, may be portable/mobile on stand
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-014	DISPENSER: disposable glove	2	1	to basin
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
MGFP-002	FLOWMETER: medical air	3	1	
MGFP-004	FLOWMETER: oxygen	3	2	quantity to suit number of oxygen outlets
FIHR-026	HOOK: coat	1	2	optional
LIFX-013	LIGHT: procedure, ceiling mounted, small	1	1	
MMMA-011	MIXER: oxygen and nitrous oxide	3	1	optional, may be mobile, on trolley or wall mounted
MMHA-008	MONITOR: patient, cardiac with vital signs	3	1	optional
ITNE-023	PRINTER: networked	3	1	optional
FQBS-052	STOOL: mobile, high, adj height	3	1	
MMGE-100	SUCTION BOTTLE	3	2	quantity to suit number of suction outlets
HYTP-037	TAPWARE: mixer, elbow levers	1	1	

Room Name | Procedure Room
Room Number PROC

AusHFG code	Description	Group	Qty	Comment
ITNE-053	TELEPHONE: handset, wall mount, handsfree	3	1	
FIRT-032	TRACK: curtain, privacy, L shaped	1	1	
MMGE-119	TROLLEY: equipment	3	1	
MMBE-043	TROLLEY: patient, examination	3	1	
MMGE-164	WORKSTATION ON WHEELS: clinical, mobile	3	1	computer may alternatively be on benchtop or wall mounted; allocation of WOWs across department to be rationalised

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITSE-006	BUTTON: duress, fixed	1	1	
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	+ indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	+ indicator button & light
ELGP-208	GPO: double, wall mounted	1	2	
ELGP-122	GPO: emergency power, single, on services panel	1	3	
ELGP-123	GPO: emergency power, single, wall mounted	1	1	optional, for cardiac/vital signs monitor
ELGP-101	GPO: single, ceiling mounted	1	1	to procedure light
ELGP-105	GPO: single, on services panel	1	3	
ELGP-109	GPO: single, wall mounted	1	1	low level, for patient trolley
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	call button on the handset
LIFX-008	LIGHT: task light, built in	1	1	
ITIN-025	OUTLET: data, double RJ45, on services panel	1	1	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	2	1 to telephone, 1 - optional, for cardiac/vital signs monitor
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	
MGAS-032	OUTLET: nitrous oxide (N2O), on services panel	1	1	optional, dependent on service requirements
MGAS-042	OUTLET: oxygen (O2), on services panel	1	2	1 is optional, quantity dependent on service requirements
MGAS-053	OUTLET: scavenge, on services panel	1	1	optional, dependent on service requirements, provide if nitrous oxide required
MGAS-062	OUTLET: suction, on services panel	1	2	1 is optional, quantity dependent on service requirements
ELPR-006	RCD: residual current device	1	4	
MMSP-026	SERVICES PANEL: wall mounted	1	1	
ELBO-015	SWITCH: light, single	1	3	1 x general room lighting, 1 x task light, 1 x examination light