

Room Name	Reception, 20m2		Room Number	RECP-20
Revision	1			
Issue Date	24.06.2022			
BRIEFING				
Briefed Area	20.00 m ²			
Hours of Operation	8am to 6pm, daily, dependent on function of unit			
Occupancy	3 staff			
Acoustics	Sound attenuation level - Medium; acoustic privacy required.			
Remarks				
Description / Special Requirements	<p>A Reception area where visitors to a Unit can be received and directed to their destination or to a Waiting Area. The Reception may also act as an administrative base as well as controlling access to the Unit.</p> <p>Additional Considerations:</p> <ul style="list-style-type: none"> Dependent on location, security glazing or shutters may be required. A recessed area for front access by wheelchair users is typically required. Depending on check in requirements at Reception, a set down area for visual access only may be sufficient. Adjustable height workstations may be provided in line with WHS policies and access for disabled staff working within the Reception area is to be considered. CCTV monitor, intercom and door release buttons linked to entry points may be required for access control depending on location. A desktop printer and labels printer may be provided as required. Printing, scanning and photocopying facilities may be consolidated with ready access from Reception to suit service requirements. Swipe card access to reception may be provided to suit security requirements. 			
SERVICES				
Electrical	BODY PROTECTED	<input type="checkbox"/>	CARDIAC PROTECTED	<input type="checkbox"/>
HVAC	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered	<input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure	<input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION	<input type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input type="checkbox"/>	LIGHTING: dimmable	<input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable	<input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof	<input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect	<input type="checkbox"/>
Security / Nurse Call	NURSE CALL SYSTEM	<input type="checkbox"/>		

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLGE-001	CEILING: plasterboard, bulkhead, paint	
CLCN-009	CORNICE: wall trim fixing	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	
DWPR-001	DOOR PROTECTION: kickplate, to 300 AFFL	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	carpet tiles are also acceptable
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	

Room Name | Reception, 20m2

Room Number RECP-20

AusHFG code	Description	Comment
WLWA-004	WALL FINISH: paint, acrylic, washable	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FIJO-051	BENCH TOP: 450D, joinery under	1	1	
FQCW-016	BIN: waste, general, 20L	3	2	
FIJO-099	CAC: cable access cap	3	3	
FQBS-018	CHAIR: office, ergonomic	3	3	
ITNE-007	COMPUTER: desktop, with display screen	3	3	dual screens may be provided to suit service requirements
FIJO-106	CUPBOARD: drawer unit, 4 equal	1	2	
FIJO-135	CUPBOARD: underbench, double door, adj shelves	1	2	
FIJO-182	JOINERY UNIT: reception desk	1	1	
FQSM-007	PEDESTAL: mobile, drawer unit, 660H	3	2	
FQGE-056	PRINTER: desktop, labels	3	1	optional
ITNE-023	PRINTER: networked	3	1	optional
WLPT-014	SCREEN: acoustic, privacy, safety glass	1	3	optional
WLPT-015	SCREEN: security, safety glass, with communication slot and pass through	1	4	optional
ITNE-049	TELEPHONE: handset, desktop	3	3	
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITSE-006	BUTTON: duress, fixed	1	1	
ELBO-003	CONTROL PANEL: lighting	1	1	optional
MEGE-007	CONTROL PANEL: temperature	1	1	optional
ITSE-025	DOOR RELEASE: access control, remote activation	1	1	optional, to external entry and/or unit entry as required
ELGP-208	GPO: double, wall mounted	1	8	3 x for BYO devices, to be located above desk for easy access, location of outlets to meet local operational/WHs requirements, 1 x optional for label printer
ELGP-223	GPO: emergency power, double, wall mounted	1	3	extent of emergency power to be determined based on service requirements, location of outlets to meet local operational/WHs requirements
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	optional for label printer
ITIN-036	OUTLET: data, triple RJ45, wall mounted	1	3	location of outlets to meet local operational/WHs requirements
ITSE-038	READER: access control, general	1	1	optional

Room Name | **Reception, 20m2****Room Number RECP-20**

AusHFG code	Description	Group	Qty	Comment
ELBO-015	SWITCH: light, single	1	1	